

TOPICAL REVIEW


The silicon photomultiplier: fundamentals and applications of a modern solid-state photon detector

To cite this article: Stefan Gundacker and Arjan Heering 2020 *Phys. Med. Biol.* **65** 17TR01

View the [article online](#) for updates and enhancements.

Recent citations

- [MATRIX16: A 16-Channel Low-Power TDC ASIC with 8 ps Time Resolution](#)
Joan Mauricio *et al*
- [A Comprehensive Survey of Readout Strategies for SiPMs Used in Nuclear Imaging Systems](#)
Shahram Hatefi Hesari *et al*
- [40 × 40 Metalens Array for Improved Silicon Photomultiplier Performance](#)
Soh Uenoyama and Ryosuke Ota



IPEM | IOP

Series in Physics and Engineering in Medicine and Biology

Your publishing choice in medical physics,
biomedical engineering and related subjects.

Start exploring the collection—download the
first chapter of every title for free.



TOPICAL REVIEW

OPEN ACCESS

RECEIVED
20 September 2019REVISED
22 January 2020ACCEPTED FOR PUBLICATION
28 February 2020PUBLISHED
19 August 2020

Original Content from
this work may be used
under the terms of the
[Creative Commons
Attribution 3.0 licence](#).

Any further distribution
of this work must
maintain attribution to
the author(s) and the title
of the work, journal
citation and DOI.



The silicon photomultiplier: fundamentals and applications of a modern solid-state photon detector

Stefan Gundacker^{1,2}  and Arjan Heering³¹ UniMIB, Piazza dell'Ateneo Nuovo, 1 - 20126, Milano, Italy² CERN, Esplanade de Particules 1, 1211 Meyrin, Switzerland³ University of Notre Dame, Indiana 46556, United States of AmericaE-mail: stefan.gundacker@cern.ch**Keywords:** SiPM, SPAD, Geiger mode avalanche, timing, TOF-PET, HEP, solid state photon detector

Abstract

The silicon photomultiplier (SiPM) is an established device of choice for a variety of applications, e.g. in time of flight positron emission tomography (TOF-PET), lifetime fluorescence spectroscopy, distance measurements in LIDAR applications, astrophysics, quantum-cryptography and related applications as well as in high energy physics (HEP).

To fully utilize the exceptional performances of the SiPM, in particular its sensitivity down to single photon detection, the dynamic range and its intrinsically fast timing properties, a qualitative description and understanding of the main SiPM parameters and properties is necessary. These analyses consider the structure and the electrical model of a single photon avalanche diode (SPAD) and the integration in an array of SPADs, i.e. the SiPM. The discussion will include the front-end readout and the comparison between analog-SiPMs, where the array of SPADs is connected in parallel, and the digital SiPM, where each SPAD is read out and digitized by its own electronic channel.

For several applications a further complete phenomenological view on SiPMs is necessary, defining several SiPM intrinsic parameters, i.e. gain fluctuation, afterpulsing, excess noise, dark count rate, prompt and delayed optical crosstalk, single photon time resolution (SPTR), photon detection efficiency (PDE) etc. These qualities of SiPMs influence directly and indirectly the time and energy resolution, for example in PET and HEP. This complete overview of all parameters allows one to draw solid conclusions on how best performances can be achieved for the various needs of the different applications.

1. Introduction

The silicon photomultiplier (SiPM) (also solid-state photomultiplier, SSPM, or multi pixel photon counter, MPPC) is a solid state photodetector made of an array of hundreds or thousands of integrated single-photon avalanche diodes (SPADs), called microcells or pixels (Renker and Lorenz 2006, Renker and Lorenz 2009, Buzhan *et al* 2003, Golovin and Saveliev 2004, Herbert *et al* 2006). In analog SiPMs all cells are independent and connected to a common readout in parallel, with each cell having its own quenching resistor. Each cell is typically square with an edge length between 10 μm (Acerbi *et al* 2018a) and 100 μm (Wagadarikar *et al* 2013).

Upon the detection of a photon the SPAD generates a large electric output signal due to internal avalanche multiplication. In an SiPM it is possible to count each fired SPAD separately: (i) in a digital fashion (digital SiPM), where each SPAD is connected to its own readout electronics (Frach *et al* 2009, Liu *et al* 2016) or (ii) by the amplitude (or charge) of the sum of the single SPAD signals as in an analog SiPM (Renker and Lorenz 2006, Renker and Lorenz 2009, Corsi *et al* 2006). Either way, the SiPM allows one to detect and count photons with high resolution and with single-photon sensitivity (Renker and Lorenz 2006, Acerbi *et al* 2015, Buzhan *et al* 2009). The internal avalanche amplification is also fast enough to obtain very good timing

information of the arrival time of the detected photons (Cova *et al* 1996, Acerbi *et al* 2014, Nemallapudi *et al* 2016), within several tens of picoseconds.

These properties, along with advantages such as low operation voltage, compactness and robustness, make the SiPM an excellent device for light detection from single photon to several thousand of photons, especially when fastest timing is a requisite. Typical applications based on low light intensity are light detection and ranging (LIDAR) (Agishev *et al* 2013, Acerbi *et al* 2018b), functional optical spectroscopy and fluorescent light detection in biology and physics (Mora *et al* 2015, Zimmermann *et al* 2013, Re *et al* 2016, Mik *et al* 2011). New arising and exciting fields can also be found in quantum physics (Kalashnikov and Krivitsky 2014) and quantum informatics (Balygin *et al* 2018). Coupled to organic or inorganic scintillators, SiPMs sense the scintillation light and/or Cherenkov light (Korpar *et al* 2011, Brunner *et al* 2014, Gundacker *et al* 2020) with highest time precision. They are used in nuclear medical imaging (Roncali and Cherry 2011, Lecomte 2009, Vinke *et al* 2009, Gundacker *et al* 2016a, Cates *et al* 2015), for gamma spectroscopy and for time tagging of high energetic particles (Herbert *et al* 2006, Benaglia *et al* 2016, Garutti 2011, Pauwels *et al* 2013). In these applications they exploit their higher granularity with respect to photomultiplier tubes (PMTs) and their insensitivity to magnetic fields. In oncological diagnostics time of flight (TOF) R&D in positron emission tomography (PET) was first studied in the 80's using fast emitting crystals, e.g. BaF₂ or CsF. However, due to their low density the timing benefits were outweighed and they could not compete with high density crystals, e.g. Bi₄Ge₃O₁₂ (BGO) (Moses 2003). The appearance of Lu₂SiO₅:Ce (LSO:Ce) or LaBr₃:Ce around 2000 made it possible to resume TOF-PET research with PMT readout. Although, the real breakthrough was only achieved by the commercial availability of SiPMs which outperformed PMTs around 2010, mainly due to their higher photon detection efficiency (PDE) and better intrinsic timing properties.

New applications such as the search for dark matter or double beta decay demand novel developments of the SiPM to extend its PDE towards the vacuum ultraviolet (VUV) or deep ultraviolet (UV) (Gola *et al* 2019). On the other hand the already mentioned LIDAR market calls for a high PDE on the other side of the spectrum in the near infrared. Furthermore new challenges in TOF-PET, high energy physics (HEP), time resolved x-ray detection and spectroscopy push developments of the SiPM to achieve single photon time resolutions (SPTRs) as much as physically possible to the few picosecond domain.

The SiPM is an already established photodetector having entered many fields from basic scientific research to social and medical applications; however it is still a device with plenty of room for further developments. This paper will give an overview of the basics of an SiPM, in order to get a deep understanding of its working principles and main parameters. It begins with the description of the SPAD physics itself, the equivalent electrical model of SPADs and SiPMs followed by a definition of SiPM noise parameters, e.g. crosstalk, afterpulse, dark count rate, etc. In the second part of the paper the focus will be placed on SiPMs in selected applications such as time of flight positron emission tomography (TOF-PET) and in HEP.



2. The SPAD

The SPAD or Geiger mode avalanche diode (GM-APD) is the smallest building block or microcell of the SiPM. The SPAD exploits avalanche multiplication as an internal gain mechanism. The avalanche breakdown process has been studied in the '60s and '70s using avalanche photodiodes operated close to breakdown voltage or above (Haitz *et al* 1963, Haitz 1964, McIntyre 1961, Oldham *et al* 1972). The first avalanche photodiodes working above breakdown, in Geiger mode, have been proposed and studied in the '80s and '90s (McIntyre 1985, Cova *et al* 1989, Dautet *et al* 1993, Bondarenko *et al* 1998, Cova *et al* 1996). Currently, SPADs are realized in silicon, with custom or CMOS processes, with quenching and from case to case the readout circuitry in-pixel, or made in different materials, like III/V materials for near-infrared range detection (e.g. InGaAs) (Ting *et al* 2019).

In the following section the basic operational principles of a SPAD will be discussed together with the electrical equivalent model and an overview of characterizing parameters accessible to experimental evaluation will be given.

2.1. Principles of operation

A SPAD is essentially a p-n junction or diode, specifically designed to be biased in reverse direction above the breakdown voltage (Cova *et al* 1996, McIntyre 1985). Depending on the applied voltage there are three different regions of operation in such a photodetector. If the voltage is low, where no additional multiplication of the generated electron-hole (e-h) pairs is happening, the diode is operating in the photodiode regime (this is illustrated in figure 1(a)). An impinging photon can create one e-h pair, which is separated by the applied field and a current proportional to the light intensity can be measured. When increasing the applied reverse voltage on the diode, the electric field becomes so high that the electrons can gain enough energy to create secondary e-h pairs via impact ionization. This is the regime of the avalanche



photodiode (APD). In the APD only the electrons can generate secondary e-h pairs, but not holes. The device shows a certain gain from several tens to hundreds and the measured current is proportional to the number of detected photons or generated e-h pairs. Because only electrons have enough kinetic energy to create additional e-h pairs, the avalanche only flows in one direction and is self quenched, i.e. no external circuit is necessary to stop the avalanche. This can be seen in figure 1(b).

If the electric field or applied reverse voltage is increased even more, above the so-called breakdown voltage, holes will also gain enough velocity in order to create secondary e-h pairs (the reason that holes need more electric field to generate secondary particles lies in their higher effective mass). This is the regime of the SPAD used in SiPMs (illustrated in figure 1(a)). In such conditions, the electric field is high enough (in the order of a few 10^5 V cm^{-1}) that a single carrier injected or generated into the depletion layer can trigger a self-sustaining avalanche process. The current increases very rapidly and the leading edge marks the arrival time of the detected photon with high precision. Subsequently the avalanche is quenched by lowering the bias voltage to or below the breakdown voltage, by a so called ‘quenching circuit’. The bias voltage must then be restored in order to allow for the detection of another photon.

There are two ways of constructing a SPAD, either n-doped on p-doped or p-doped on n-doped, which can be seen in figure 2. Due to the reverse-biasing the generated electrons always flow in the direction of the n-doped connection. The avalanche triggering probability is the likelihood of an electron or hole passing the p-n junction to generate enough secondary e-h pairs in order to trigger a self-sustainable avalanche. This quantity is of course dependent on the SPAD structure and electric field, given by the applied bias voltage or excess bias. As already mentioned and illustrated in figure 3(a) (Oldham *et al* 1972), the avalanche triggering probability of electrons is higher than for holes. Hence, the avalanche is predominantly triggered by electrons, or in order to increase the PDE of the device electron avalanche triggering is preferred.

Photons in the blue to UV are absorbed closer to the surface of the SPAD, which is illustrated in figure 3(b), showing the absorption length in silicon. This implies that in the case of the p-on-n structure blue light will predominantly generate electrons close to the surface, which will traverse the junction towards the




Figure 3. (a) The avalanche triggering probability of electrons and holes in a SPAD (reproduction from Oldham *et al* 1972). (b) Light absorption length in Silicon (data from Green and Keevers 1995).




Figure 4. Equivalent electrical circuit of the SPAD with integrated quenching resistor.

n-doped region, connected to the positive pole of the bias voltage. Contrarily, light in the red with larger wavelengths will generate electron-holes deeper in the SPAD further away from the surface. In this case electrons are collected rather quickly traversing less material, giving them a lower chance of triggering an avalanche. The holes traversing the SPAD in the opposite direction, however, have a smaller avalanche triggering probability and, hence, the PDE for a p-on-n SPAD is lower in the red part of the spectra and higher in the blue. Consequently, a n-on-p SPAD is more sensitive in the red for light detection, because the above arguments are reversed. Of course in the design of a SPAD additional factors like the exact doping profile, drift regions, field distribution and junction depth will influence the final detection efficiency (Acerbi and Gundacker 2019).

2.2. Electrical equivalent circuit of the SPAD

The analog SPAD is essentially modeled as a parallel connection of the internal resistance of the diode space-charge region, i.e. R_d , and the inner depletion layer capacitance C_d , as can be seen in figure 4. The diode capacitance C_d can further be the sum of the SPAD area capacitance and any kind of perimeter or parasitic capacitances. Figure 4 also shows the integrated quenching circuit of an analog SPAD (Corsi *et al* 2006). The quenching circuit consists of the quenching resistor R_q and a parasitic capacitance C_q in parallel. C_q is responsible for a fast signal extraction (Acerbi *et al* 2014, Marano *et al* 2013), which can be beneficial, especially for fast timing applications, and is therefore a design parameter for optimal performance along with R_q .

A triggered avalanche in the SPAD, either by a detected photon or noise event is modeled by closing the switch in figure 4 (Cova *et al* 1996, Marano *et al* 2014). This starts to discharge the capacitor C_d and provokes an exponential voltage drop at the internal node between C_q and C_d , initially being charged at the bias voltage of the SPAD applied between cathode and anode V_{bias} . It should be noted that upon closing the switch, the capacitance C_q is charging as well via R_d , provoking that the full charge involved in the recharging process is $C_q + C_d$ and, hence, the voltage discharge time constant at the internal node given by $\tau_r = R_d \cdot (C_q + C_d)$ (neglecting the influence of R_q , which usually is highly resistive). The voltage source in figure 4 is in most of the models set to the breakdown voltage V_{bd} , which gives the maximum voltage drop at the internal node being the bias voltage V_{bias} minus the breakdown voltage V_{bd} , i.e. the overvoltage $V_{ov} = V_{bias} - V_{bd}$.

The discharge of C_d and recharge of C_q is stopped when the current I_d through R_d reaches a certain value, i.e. the 'threshold current', which is the minimum value of the current to get a self sustainable avalanche process. This value is a bit higher than the asymptotic minimum value I_{df} that I_d would reach. This asymptotic current I_{df} is given by the overvoltage V_{ov} divided by $R_q + R_d$ (Seifert *et al* 2009), i.e. $I_{df} = V_{ov} / (R_q + R_d) \sim V_{ov} / R_q$. Once the avalanche is quenched the cell recovery or recharge time is given by $\tau_{recharge} = R_q \cdot (C_q + C_d)$. Because the avalanche is quenched close to the asymptotic minimum value of I_d the total charge which has to be provided from the outside via the SPAD anode and cathode is given by $V_{ov} \cdot (C_q + C_d)$, which represents the SPAD gain multiplied by the electron charge.

In literature, the avalanche is sometimes modeled via a pulsed current source (Corsi *et al* 2006, Corsi *et al* 2007) in place of the series of the switch, the breakdown V_{bd} power supply and R_d (Seifert *et al* 2009). According to Thévenin's theorem both approaches are equivalent, however can simulate different angles of the problem. The current source can take into account the time structure of the avalanche development, whereas the model with the switch and V_{bd} source can describe the avalanche quenching or non-quenching.

2.3. Breakdown voltage and multiplication gain

As already discussed the reverse current-voltage curve shows a divergence at a certain bias voltage, the breakdown voltage (V_{bd}), at which the multiplication factor (M) (Kindt and Zeijl 1998) diverges. The multiplication factor is defined as the number of secondary carriers produced per each primary one. Above the breakdown voltage the photodetector works in Geiger mode and becomes a SPAD based detector. Besides the relatively high gain delivered by the Geiger mode operation and in fact defined by the quenching circuit, the real advantage lies in an almost gain independent excess noise factor, which is in contrast to an APD. The value of the breakdown voltage depends on the internal structure of the diode, i.e. the doping profiles at the p-n junction, and on the temperature.

Geiger discharge is reached when enough secondary (e-h) pairs are generated by impact ionization, in order to trigger a diverging avalanche process. Mathematically this can be described by the impact ionization rates α_n and α_p of electrons and holes, respectively, per unit distance. Together with the depletion region width W the breakdown voltage is reached when the ionization integral in equation (1) is equal to one (Maes *et al* 1990).

$$\int_0^W \alpha_n \cdot \exp\left(-\int_0^x (\alpha_n - \alpha_p) dx'\right) dx = 1 \quad (1)$$

More sophisticated calculations of realistic structures are generally done within Technology Computer-Aided Design (TCAD) simulations, solving the Poisson equation along all trajectories. A general study of the breakdown voltage has been performed in (Serra *et al* 2011) and the following conclusions have been found: (1) V_{bd} increases with the thickness of the depletion region, (2) the temperature dependence of V_{bd} increases with the depletion region thickness and (3) in thin depletion regions the reproducibility of V_{bd} is higher. Hence, in view of optimizing the breakdown voltage it is more advantageous to work with thin depletion regions, which is possible if blue to UV light should be detected. Applications demanding red and infrared light detection, and therefore thicker depletion regions, might be more limited by breakdown uniformity and temperature stability.

The gain defined in equation (2) states the number of charge carriers collected per avalanche. In analog SPADs with integrated quenching resistors the gain is generally well defined due to a uniform production process of the internal capacitances C_q and C_d . If the quenching circuit is external, parasitic capacitances can have a significant influence and, hence, observed gain.

$$\text{Gain} = \frac{\text{avalanche_charge}}{q} = \frac{V_{ov} \cdot (C_q + C_d)}{q} \quad (2)$$

In equation (2), q is denoting the elementary charge $q = 1.602 \cdot 10^{-19}$ C. The gain is typically in the order of 10^5 to 10^7 (Piemonte *et al* 2016, Acerbi *et al* 2015) in analog SPADs and produces a single photon signal




Figure 5. DCR for NUV-HD-SF (Standard Field) and NUV-HD-LF (Low Field) devices as a function of $1/T$ and overvoltage. Reproduction from Acerbi *et al* (2017).

well above the electronic noise level, which gives the SPAD and SiPM excellent single photon counting capabilities (Buzhan *et al* 2009).

2.4. Dark count rate (DCR)

In silicon the primary dark count rate is due to the thermal generation of carriers by states in the bandgap and it can be modeled using Shockley–Read–Hall (SRH) statistics (Vincent *et al* 1979). This behavior is dependent on the temperature as $1/T$ and the dark current in silicon drops by a factor of 2 about every 10°C . In SiPMs at room temperature the same behavior can be seen and the DCR increase and reduction versus temperature is equivalent with this factor. However, because of the high electric fields in SiPMs a saturation of the dark count reduction at low cryogenic temperatures due to trap assisted tunneling can be found, which is in contrast to other silicon photodetectors with gain one, e.g. PIN diodes. This tunneling effect dominates at low temperatures and is strongly dependent on the internal electric field strength. Figure 5 shows the DCR in two similar FBK NUV-HD SiPMs designed with a standard and low internal field structure at different overvoltages, demonstrating the tunneling electric field dependence (Acerbi *et al* 2017).

For the dark count rate it is interesting to mention that only a small percentage of SPADs is responsible for the mostpart of the observed counts in an SiPM. In an analog SiPM the dark count rate can only be improved by better production processes and material pureness as all SPADs are connected in parallel. In the case of the digital SiPM it is thinkable to selectively switch off these ‘screamer’ SPADs in order to reduce the DCR (Mandai and Charbon 2012).

2.5. Afterpulse

Upon a primary event (dark count or detected photon) a secondary delayed event can be created with its amplitude or gain being lower than the primary event itself. This type of correlated noise is called afterpulse. The cause of afterpulse is the trapping and release of charge carriers in the high-field region. Deep and shallow traps are the mediators for afterpulsing with exponential release time characteristics. The afterpulse probability depends on the number of traps, release time constants and the recharge time of the SPAD. Thus, in order to reduce the afterpulse probability (or at least its visible effect), the recharge time constant can be tuned in order that most of the trapped charge carrier release happens when the cell is not yet (fully) recharged. Consequently a long SPAD recharge time generally reduces the afterpulse probability.

Afterpulse can be optically induced as well. During each avalanche secondary photons are produced (Gautam *et al* 1988). The amount has been estimated to $3 \cdot 10^{-5}$ photons per avalanche carrier (Lacaita *et al* 1993, Otte 2009). These photons can be re-absorbed in the same SPAD in the neutral region. The generated charge carriers can diffuse to the high field region triggering an avalanche. In the substrate the carrier release time can be between a few nanoseconds to hundreds of nanoseconds (Acerbi *et al* 2015). The afterpulse probability can be reduced by carefully selecting the material, like using a low-lifetime substrate.




Figure 6. (a) Picture of an analog SiPM (HPK S10931-3050P) with zoom on the individual SPADs (indicated by the arrow). (b) In an analog SiPM all SPADs with integrated quenching resistor are connected in parallel.




Figure 7. Equivalent electrical circuit of the SiPM. Switch represents the avalanche ignition, whereas the diode series resistance is given by R_d , the diode capacitance by C_d , the quenching part by R_q and C_q . The non-active not triggered cells are represented in the passive part and the parasitic part shown as series and parallel parasitic components. N_f denotes the number of simultaneously fired SPADs and N_{tot} is the total number of SPADs in the SiPM.

3. The analog SiPM

In order to keep the dark count rate low and the signal response of the SPAD fast, its dimensions should be lower than $\sim 100 \mu\text{m}$. Additionally a single SPAD shows a certain dead time after being fired. In order to build a useable photodetector it is necessary to combine many SPADs to an SiPM. In the case of the analog SiPM the SPADs are connected in parallel, as can be seen in figure 6. If one SPAD is firing a certain output signal is recorded, if two SPADs are triggered at the same time two similar signals overlap and form a signal with double the amplitude and so on. In this sense the analog SiPM allows one to count the number of SPADs fired by integrating the charge in time, which is proportional to the number of photons detected (as long as the number of photons detected is smaller than the total amount of SPADs available). Presently the trend is to produce SiPMs with very small SPADs in the $10 \mu\text{m}$ range in order to increase the dynamic range.

3.1. Electrical equivalent circuit of the analog SiPM

As already discussed, the analog silicon photomultiplier (SiPM) is an array of SPADs connected in parallel. In the electrical equivalent model (seen in figure 7) the differences in the SPAD equivalent circuit are the additional passive components of the other not-triggered SPADs plus the grid inductances and capacitances (Corsi *et al* 2006, Marano *et al* 2014, Seifert *et al* 2009). For single photon detection these additionally not triggered cells add up to a non-negligible (several 100 pF) capacitance on the input of the amplifier electronics, which depending on the bandwidth and readout-scheme can change the single SPAD signal to a large extent.

An avalanche in one SPAD provokes that C_d is discharging via R_d , which leads to a voltage drop across C_q inducing a current which is charging C_q via R_d . This external current has to be provided from the outside and is proportional to the gain of the SPAD. However, the fast high-frequency part of this current initially is provided from the capacitance of the many inactive cells, which depending on the front-end electronic design can either reduce the signal amplitude or the speed of the signal, as briefly discussed below.

Depending on the SiPM readout, in “voltage” or “current” mode, different frequency behaviors of the sensed signal can be observed. For example, sensing only the voltage drop between anode and cathode of the SiPM leads always to a fast signal component mediated via C_q . However, the charge of this signal is divided between the large parasitic capacitance of the inactive cells and the small C_q , hence, for larger SiPMs the fast voltage signal amplitude is reduced by the ratio of the capacitances (capacitive divider). Still, the signal speed remains constant for large SiPMs. On the other hand if one has a transimpedance amplifier (“current mode”) the input impedance will play a crucial role. If the input impedance of the amplifier is not low enough then the impedance of the parasitics of the SiPM and inactive cells will filter the high-frequency part of the signal, smearing it in time. Even so, by measuring the current an integration of the whole signal in time will always give similar (gain) values independent of the SiPM size. In a real system, however, both readout modalities are always present. Hence, the exact front-end design is a crucial input parameter for any simulations, e.g. in SPICE, in order to understand the measured SiPM signals.

In the frequency domain the absolute impedance of the SiPM can be obtained as in equation (3), if no SPAD is firing. This function can serve to estimate the SiPM’s equivalent circuit component values by measuring $|Z|$ in the frequency range and fitting to the model (Scheuch *et al* 2015).

$$|Z(\omega)| = \left| j\omega L_{\text{par}} + R_{\text{par}} + (j\omega C_g + N_{\text{tot}} Y_{\text{cell}})^{-1} \right| \quad (3)$$

$$Y_{\text{cell}} = \left[\frac{1}{j\omega C_d} + \frac{1}{R_q^{-1} + j\omega C_q} \right]^{-1} \quad (4)$$

Y_{cell} (also called Y_{pix}) is the admittance of the single cell, which is then multiplied by the total number of pixels in the $|Z(\omega)|$ calculation, since they are all supposed inactive. For intermediate frequencies $|Y_{\text{cell}}|$ is dominated by C_d . The capacitive component of $|Z|$ is $\sim N_{\text{tot}} \cdot C_d$. At high frequencies the contribution of C_q dominates over the R_q one, thus the capacitive component of $|Z|$ is $\sim N_{\text{tot}} \cdot \frac{C_d \cdot C_q}{C_d + C_q}$.

Because of epitaxial layer depletion, the impedance will depend on the absolute voltage applied to the SiPM. The smaller depletion at low bias will give a higher C_d , whereas a progressively higher depletion reaching the breakdown voltage will lower the value of C_d . The change of depletion region thickness is relevant above breakdown also, a small dependence of the measured impedance on the overvoltage will occur, even though a direct impedance measurement above breakdown is generally difficult. Moreover, a change in the equivalent circuit as a function of the number of pixels firing can be seen, leading to a slight change in the output signal (due to different load and charge partitioning).


Neglecting the parasitic part in equation (3) the complex impedance $Z(\omega)$, or the complex admittance $Y(\omega)$, can be rewritten as in equation (5) (Seifert *et al* 2009), further assuming that no cells in the SiPM are firing.

$$\begin{aligned} Y(\omega) &= \left(\frac{1}{G(\omega)} \parallel \frac{1}{j\omega C(\omega)} \right)^{-1} = G(\omega) + j\omega C(\omega) \\ &= \left[\left(\frac{R_q}{N_{\text{tot}}} \parallel \frac{1}{j\omega N_{\text{tot}} C_q} + \frac{1}{j\omega N_{\text{tot}} C_d} \right) \parallel \frac{1}{j\omega C_g} \right]^{-1} \end{aligned} \quad (5)$$

where $G(\omega)$ and $C(\omega)$ are the measurable parallel conductance and capacitance of the SiPM, which can be obtained with a precision LCR meter. Equation (5) can be solved to obtain the solution for C_d and C_g from $G(\omega)$ and $C(\omega)$, as can be seen in equations (6) and (7), respectively.

$$C_d = \sqrt{\frac{1 + \omega^2 (C_d + C_q) R_q^2}{\omega^2 N_{\text{tot}} R_q}} G(\omega) \quad (6)$$

$$C_g = C(\omega) - N_{\text{tot}} C_d + \frac{\omega^2 C_d^2 R_q^2 N_{\text{tot}} (C_d + C_q)}{1 + \omega^2 R_q^2 (C_d + C_q)^2} \quad (7)$$



The sum $C_d + C_q$ can be measured via the gain of the SiPM, $\text{Gain} = (V_{\text{bias}} - V_{bd})(C_d + C_q)/q$ and the quench resistor value R_q can be obtained from the forward current measurements, knowing the number of cells in the SiPM (N_{tot}). This defines all parameters of the SiPM equivalent model except the diode series resistance R_d , which in theory could be estimated by the single SPAD signal rise time. However, other effects such as bandwidth limitations of the used electronics and parasitic inductances makes the direct measurement of R_d via the signal rise time unreliable. In most of the cases, however, R_d can be assumed to be small in the range of $\sim 1 \text{ k}\Omega$ and simulations show that changing R_d in a broad range does not impact the model output too much (Seifert *et al* 2009).

3.2. IV curve and breakdown voltage determination



The breakdown voltage (V_{bd}) is one of the most important parameters of the SiPM, because the gain, PDE and other parameters are best specified versus the overvoltage applied to the SiPM. There are two ways of defining V_{bd} . The first method that is widely used is to measure the gain from the first photoelectron peak in the pulse height spectrum as a function of the bias voltage. In this method the V_{bd} is then found by extrapolating the gain to zero (Acerbi and Gundacker 2019, Klanner 2019).

In the second method, the maximum of the derivative is used (Musienko 2014) to find at which bias voltage the Geiger mode (or SPAD breakdown) starts. To get sufficient accuracy with this method it is sometimes necessary to inject some light into the SiPM. This is especially the case if small SiPMs or SiPMs with low gain and low dark count rate are to be measured. Figure 8(a) shows the IV curve of the SiPM under illumination of different constant current biased LEDs. In figure 8(b) the calculated derivative where the measured V_{bd} is independent of the LED intensity is shown. Further, it can be seen that only limited accuracy of the measurement was reached with very low external light intensity (LED1). The IV breakdown determination gives in general slightly larger values of maximum 0.5 V higher as compared to the method determining the breakdown by extrapolating the SPAD gain to zero. In our opinion the IV method is more correct, because in reality the gain at V_{bd} is not really zero since the SiPM already has a small avalanche gain before the Geiger mode starts (avalanche photodiode regime). An additional advantage of the IV method is that it can be easily obtained, and in general measurement of the IV characteristic is fast and applicable for device monitoring in the production process.

3.3. Prompt, delayed and external crosstalk

A summary plot of the various noise types is given in figure 9, represented by their observable analog waveforms. The plot shows the primary noise source of an SiPM; the dark count rate (DCR), which is indistinguishable from detected photons. Correlated noise sources are afterpulsing, prompt-, delayed- and external-crosstalk. The term correlated noise indicates that this type of noise is a follow-up process of a primary event, i.e. an avalanche triggered either caused by a thermally generated (e-h) pair (DCR) or caused by a detected photon.

As already mentioned, each avalanche in a SPAD produces optical photons due to hot-intraband luminescence (Lacaita *et al* 1993). These photons can traverse to a neighboring SPAD and trigger an avalanche giving rise to prompt or direct crosstalk, as is shown on the very left in figure 10. The direct crosstalk probability has its peak value when the primary avalanche has reached roughly its maximum of produced e-h pairs. According to a study of the avalanche process in SPADs (Ingargiola *et al* 2011) this



happens some hundreds of picoseconds after the initial event. Due to the small distance the light has to travel, prompt crosstalk is timed very close to the primary event, starting from almost no time delay to a delay of, at maximum, several hundreds of picoseconds.

Delayed crosstalk or delayed optical crosstalk is generated by secondary avalanche photons, which are absorbed in the un-depleted region of a neighboring SPAD (see figure 10, middle). These photon-generated minority carriers can reach the multiplication region of the SPAD by diffusion and trigger an avalanche. The carrier diffusion time can be quite long and the delays are generally long enough that the delayed crosstalk events can be separated from the primary events. However, part of the delayed crosstalk events will occur too shortly following the first avalanche in which case this type of noise is not distinguishable from prompt crosstalk. It should be mentioned that delayed afterpulsing might lead to the same type of signal at the SiPM terminal as delayed crosstalk, this especially if the SPAD of the afterpulse event was almost or already fully charged. Since the thickness of the superficial un-depleted region of the entrance window is normally very small, it can be assumed that the most important contribution to the delayed crosstalk comes from the region below the active area (Piemonte and Gola 2019).

Another type of crosstalk is of external nature, as can be seen in figure 10 (right hand side). Because the optical photons generated by the primary avalanche are isotropic, a good part will exit via the active side of the SiPM. A protective glass window or epoxy resin will reflect a part of these photons back to the SPADs via total internal reflection, generating external crosstalk. The secondary avalanches are not restrained to neighboring SPADs anymore and the external crosstalk probability might exceed the other sources of crosstalk. In fact, by coupling a crystal wrapped in reflective material on top of the SiPM (like in PET applications) this type of correlated noise can even limit the operational range of an SiPM, as can be seen in figure 11 (Gola *et al* 2014), where the ‘second breakdown’ is defining the maximum SiPM bias voltage applicable for stable operation. It can be seen that this value is around 11 V overvoltage in the case of a cleaned SiPM, without protective resin on top of the active area. Gluing a scintillator on top of the NUV device produced at Fondazione Bruno Kessler (FBK), used in this study, reduces the maximum applicable overvoltage to about 7 V. This behavior has also been described in other publications (Nemallapudi *et al* 2015, Gundacker *et al* 2016a).

A way to reduce prompt crosstalk is to introduce optical trenches in-between the cells. Delayed crosstalk can be minimized by reducing the un-depleted region thickness, using a substrate with a low minority carrier lifetime (Acerbi *et al* 2015), a buried junction below the active area to prevent diffusion or by extending the trenches deep into the substrate to confine the optical photons within the same SPAD. Crosstalk in general




Figure 11. Reverse bias currents measured at different temperatures with and without scintillators of different lengths coupled to the SiPM via optical glue. Reprint from Gola *et al* (2014).

and in particular external crosstalk can be minimized by reducing the SPAD gain, which will reduce the produced e-h pairs and, hence, the generated hot-intraband optical photons. Indeed, current research is moving in the direction of reducing the SPAD size down to sizes of $15\mu\text{m}$ and smaller, which reduces the SPAD gain, increases the SiPM dynamic range and shows advantages in radiation hardness.

3.4. Excess noise factor (ENF)

For an ideal photodetector the energy and time resolution is limited by pure photo-statistics. Meaning that for the real number of photoelectrons N_{phe} (primary SPADs triggered by the incoming photons) created the event to event fluctuations are given by the standard deviation or root mean square (rms) and is equal to the $\sqrt{N_{\text{phe}}}$. However, the non ideal characteristics of the SiPM, like the inter SPAD crosstalk and integrated afterpulsing will contribute and increase the signal. Hence, by measuring the mean charge or pulse height distribution and dividing it by the SPAD gain one will get a larger value than the real N_{phe} . This is often referred to as excess charge factor (Klanner 2019):

$$\text{ECF} = \frac{\langle Q \rangle}{\langle Q_N \rangle} \quad (8)$$

where $\langle Q \rangle$ is the average total charge measured and $\langle Q_N \rangle$ is the average charge of the primary photoelectrons. Since this excess charge from crosstalk and afterpulsing appears as an artificial gain in the system the resolution of the pure primary Poisson-statistics is degraded and is referred to as the excess noise factor:

$$\text{ENF} = \frac{(\sigma_Q / \langle Q \rangle)^2}{(\sigma_{Q_N} / \langle Q_N \rangle)^2} \quad (9)$$

where σ_Q is the rms of the charge distribution in the measured spectrum and $\langle Q \rangle$ the average total charge. Further σ_{Q_N} and $\langle Q_N \rangle$ represent the rms fluctuation and average charge of the primary photoelectrons. Since the crosstalk and afterpulsing are strongly dependent on the internal electric field strength in practice the ENF is unity around the breakdown voltage and increases with the overvoltage. Very successful R&D on trench technology to optically isolate the SPADs has been done to decrease the crosstalk to create SiPMs for high resolution detectors. The best low crosstalk SiPMs have almost unity ENF up to 5 V overvoltage. As previously mentioned, the SPAD crosstalk is also dependent on the reflections on the top surface. So if an epoxy layer or other reflecting medium, like a scintillating crystal wrapped in reflective material, is placed on top of the SiPM it can increase the ENF significantly.

3.5. SiPM saturation and non-linearity

In applications where one expects large signals, the limited number of SPADs in an SiPM causes saturation of the signal. The first commercial SiPMs had a limited SPAD size of minimum $50\mu\text{m}$ to $100\mu\text{m}$, but in the last years much smaller SPAD sizes (down to $10\mu\text{m}$) are greatly improving the linear range. However, with very small SPAD sizes the relative dead space between SPADs increases, which decreases the PDE. So a trade off

needs to be made between PDE and linear range. The general equation for the number of triggered SPADs ($N_{\text{fired cells}}$) as a function of the number of photons (N_{photon}) and total number of SPADs in the SiPM (N_{total}) based on the statistical process on a uniform illumination of the SiPM can be given by equation (10) (Renker and Lorenz 2009, Grodzicka-Kobylka *et al* 2019).

$$N_{\text{fired cells}} = N_{\text{total}} \cdot \left(1 - \exp \left[- \frac{N_{\text{photon}} \cdot \text{PDE} \cdot \text{ENF}}{N_{\text{total}}} \right] \right) \quad (10)$$

Respective plots and measurements of various SiPMs can be found in Gruber *et al* (2014), which describes ‘over-saturation’ effects of some devices as well. Similar effects and complete phenomenological parametrizations can be found in Bretz *et al* (2016). Nevertheless, in most applications the light source does not illuminate the SiPM completely uniformly and a good simulation or measurement needs to be made in order to calculate the correction factors accurately. In addition, the situation gets more complex if the light source has a larger decay time than the SiPM recovery time, causing the cells to be able to be triggered multiple times within the same light pulse (Vinogradov *et al* 2011, Grodzicka-Kobylka *et al* 2019). As a consequence the linear range using small SPAD sizes is also increased by the shorter recovery time due to the lower capacitance of the smaller SPADs ($\tau_{\text{recharge}} = (C_d + C_q) \cdot R_q$).

3.6. PDE

In almost every application of SiPMs it is important to optimize the PDE and there are many different SiPMs available for use from the UV to the infrared (IR). The PDE quantifies the ability of a single-photon detector to detect photons. This is the ratio between the number of detected photons and the photons arriving at the detector. The general formula for the PDE of the SiPM is given in equation (11).

$$\text{PDE}(V_{ov}, \lambda) = \text{QE}(\lambda) \cdot P_T(V_{ov}, \lambda) \cdot \text{FF}_{\text{eff}}(V_{ov}, \lambda) \quad (11)$$

Here QE is the quantum efficiency, P_T the avalanche triggering probability, V_{ov} is the overvoltage and FF_{eff} is the effective geometrical fill-factor. The QE of silicon is dependent on the wavelength λ and for UV applications manufacturers have to use special protective coatings to optimize the QE in the UV.



The fill factor or also called geometric factor is defined as the active area of all SPADs divided by the total area of the SiPM. The inactive area is created in order to separate the SPADs electrically and optically from each other. For the bigger SPAD sizes of $50 \times 50 \mu\text{m}^2$ the fill factor can be as large as 80% where for the smallest cell sizes of $10 \times 10 \mu\text{m}^2$ it is limited to 30%. As the fill factor is linked mostly to the SPAD size the linear range required in the application needs to be taken into account. It is worth mentioning that the best fill factor in modern small size SPAD SiPMs is attained using transparent metal film quenching resistors (MFQR) versus the more standard option of a non transparent Polysilicon quenching resistor which can also be responsible for more dead space. The geometric fill factor is typically not included in the PDE calculation when characterizing a single SPAD, in this case the photon detection probability PDP is quoted.

The Geiger mode probability or avalanche trigger probability is a function of the overvoltage and the wavelength of the incoming photons. The ionization rate is higher for the electrons than for the holes and it is therefore much more efficient to collect the electrons than the holes for each e-h pair generated by an incoming photon. Because the absorption depth in silicon is growing with the wavelength, about 10 nm in the UV to 10^{th} of microns in the visible range, it will depend on the SPAD structure if the holes or electrons are most efficiently collected.

There are two kind of structures illustrated in figure 12, where the authors in Piemonte and Gola (2019) plot the electron and hole Geiger probability versus the two widely used SiPM structures called n+ on p and p+ on n. Generally for wavelengths above 500 nm the n+ on p structure will have a superior PDE and for wavelength below 500 nm one does better using a p+ on n structure.

Because the electric field over the junction increases with the overvoltage the PDE will increase quickly and usually saturates around 5–7 V overvoltage. Of course by increasing the overvoltage the dark count rate (DCR) will also increase, so an optimum can be found which is usually also dependent on the amplifier noise.



To measure the PDE special attention has to be given to correlated noise sources in SiPMs, i.e. the crosstalk, afterpulse and dark count rate (Eckert *et al* 2010, Zappala *et al* 2016, Otte *et al* 2006, Otte *et al* 2017). Upon the detection of one impinging photon the measured output signal can be caused by either a real single SPAD firing or a multiple of the single SPAD signal due to correlated noise. One method, in order to avoid a bias of the PDE measurement by crosstalk or afterpulsing, is to exploit Poisson statistics. By measuring the ratio of how many times there was no photon detected (zero or pedestal events) N_{ped} to the total amount of events N_{tot} , the mean number of photoelectrons detected n_{pe} can be expressed, as in equation (12) (Eckert *et al* 2010). Additionally, a dark scan with no light illumination has to be performed in



order to correct for possible dark count events in the integration window $N_{\text{ped}}^{\text{dark}}$ and $N_{\text{tot}}^{\text{dark}}$.

$$n_{pe} = -\ln\left(\frac{N_{\text{ped}}}{N_{\text{tot}}}\right) + \ln\left(\frac{N_{\text{ped}}^{\text{dark}}}{N_{\text{tot}}^{\text{dark}}}\right) \quad (12)$$

Presently many SiPM producers reach very high and comparable PDE values up to 60% (figure 13). The evolution in PDE made by FBK and HPK is summarized in figure 14, showing the advancements of devices from 2010 until 2018. Two main reasons for the seen increase in PDE have been: (1) a better geometric fill factor by reducing the dead-space between the SPADs (better lithographic processes) and (2) a reduction in optical crosstalk and afterpulse, which made it possible to operate the SiPMs at higher overvoltages boosting



the avalanche triggering probability by a higher electric field. Further, operating at higher overvoltages the effective fill factor will be slightly increased due to the electric field saturating in a larger area of the SPAD, especially at the edges.

3.7. Single photon time resolution (SPTR)

With the maturity of SiPMs in many aspects the SPTR is one of the few parameters which can still show major improvements. This is especially important for applications like TOF-PET, Cherenkov radiation detection, LIDAR and time correlated single photon counting setups. Especially in the case of analog SiPMs, the front-end readout, bandwidth and electronic noise play a crucial role in achieving the intrinsic SPTR limits imposed by the SiPM itself. This can be understood by the well know equation (13), expressing the part of the single photon time resolution (SPTR) only caused by the electronic readout with $\sigma_{v_{noise}}$ the rms of the electronic noise floor and $dv/dt_{@threshold}$ the slew rate of the signal at a given leading edge threshold level (Nemallapudi *et al* 2016, Gundacker *et al* 2020). It can be seen that a low noise amplifier and/or a faster signal with a fast rise time (higher bandwidth) can lead to improved timing behavior.

$$\sigma_{elec. timing} = \frac{\sigma_{v_{noise}}}{dv/dt_{@threshold}} \quad (13)$$

Recently, major achievements have been accomplished using high-frequency electronics, making use of the fast signal mediated via the SPAD quenching capacitance. SPTR values as low as 90 ps FWHM have been measured illuminating an FBK NUV-HD SiPM uniformly with a picosecond-laser (Cates *et al* 2018), by subtracting the picosecond laser pulse width of 42 ps FWHM a value of 80 ps FWHM was measured.

Nevertheless, even in this case with optimized electronics the real intrinsic SiPM SPTR was shown to be 70 ps FWHM by estimating and subtracting the influence of the front-end electronic noise (according to equation (13)). Indeed different producers show very different performance regarding the SPTR, as can be seen in figure 15. This is mainly explained by different SPAD technologies and the different interconnection schemes between the SPADs applied by the various producers. Furthermore, up until now it was difficult to measure the intrinsic SPTR performance of SiPMs, which made targeted improvements difficult, which is in contrast to the PDE, DCR, afterpulse and crosstalk for example.

3.8. Temperature dependence of SiPM parameters

The breakdown voltage of the SiPM is temperature dependent, because the mean free path for electrons decreases with increasing temperature, hence a higher electric field is required to start the avalanche process. Since the gain is only dependent on the cell capacitance and the applied overvoltage, the gain of the SiPM increases by lowering the temperature due to the breakdown voltage shift, i.e. effectively the overvoltage is increased. For different SiPMs we find different breakdown voltage shifts depending on their junction thickness. For shallow junctions with a depletion voltage of only 25 V this shift is in the order of 20 mV/°C, where for wider junctions with a depletion voltage of 75 V this parameter is in the order of 60 mV/°C. In applications where it is not convenient to stabilize the temperature itself it is possible to stabilize the overvoltage by using this coefficient with a feedback loop to a simple temperature sensor.

Another parameter strongly dependent on the temperature is Shockley–Read–Hall (SRH) induced dark counts as discussed in chapter 2.4. Lowering the temperature can effectively lower the DCR until the point where tunneling overtakes.

Other parameters as the SPTR, PDE or crosstalk probability are more or less stable with temperature as long as the overvoltage is fixed. Especially in commercial applications like PET, LIDAR in automotive or in spectroscopy, temperature ranges are commonly not exceeding the $-40\text{ }^{\circ}\text{C}$ to $85\text{ }^{\circ}\text{C}$ range and therefore secondary effects on PDE, SPTR and other factors which can be observed at very extreme temperatures are not an issue. However, it should be mentioned that if the quenching resistor is made out of polysilicon the resistive value can change with temperature, which then can be the cause of a changed signal shape and even manifest in a non-proper avalanche quenching at high overvoltages and certain temperatures.


3.9. Electronic readout of SiPMs

There are several approaches to reading the signal of analog-SiPMs, all of them having their advantages and disadvantages. Typically the readout electronic has to cope with the remarkably high terminal capacitance of the SiPM and its high overall gain, which is very unevenly distributed in time. As already mentioned a fast component of the signal is almost immediately transferred to the SiPM output via the quenching capacitance C_q , only mediating a small part of the overall gain. The rest of the gain is delivered via the quenching resistor R_q (recovery of the cell) with a time constant $\tau_R = R_q \cdot (C_d + C_q)$. In view of integrating the front-end in ASICs with several tens to hundreds of channels and further to PET or HEP systems with thousand of channels, the power consumption plays a crucial role for the electronics design. Limiting the power consumption inevitably sets compromises on the best achievable performances and also on the readout architecture.

An overview of the SiPM timing characteristics with coupled front-end electronics can be given by considering the SiPM equivalent circuit in figure 7, neglecting the parasitic inductance L_{par} and resistance R_{par} . By connecting the front-end input and its characteristic resistance R_{in} between the cathode and anode of the SiPM it can be derived that the fast part of the input voltage transient seen by the preamplifier (the voltage over R_{in}) is equal to equation (14) (Calò *et al* 2019).

$$V_{\text{in}} = \frac{Q_F}{C_{\text{HF}}} \cdot e^{-t/\tau_F} \quad (14)$$

With $Q_F = Q_{\text{tot}} C_q / (C_q + C_d)$ being the fraction of the total charge Q_{tot} provided via the quenching capacitor C_q . Considering the value of R_{in} being sufficiently low, commonly the case for SiPM readout, the time constant $\tau_F = R_{\text{in}} C_{\text{HF}}$. The term C_{HF} is the equivalent capacitance of the detector at high frequencies, given by $C_{\text{HF}} = C_g + N_{\text{tot}} \frac{C_d C_q}{C_d + C_q}$. In practice equation (14) states that the fraction of the charge flowing over C_q is almost immediately collected on the high frequency equivalent capacitance of the detector C_{HF} and then discharged via the amplifier input impedance R_{in} . In this respect the fast component of an SiPM is in its speed basically only limited by the bandwidth of the amplifier and the avalanche growth in time itself. Indeed rise times of the single SPAD signal below 700 ps (10–90% of the SPAD amplitude) have been measured with amplifiers of 1.5 GHz using FBK SiPMs of $4 \times 4\text{ mm}^2$ size (Gundacker *et al* 2020). It can be further stated that the input capacitance of the amplifier C_{in} does not play a significant role, as usually C_{HF} is much higher. Equation (14) also shows that a higher device capacitance (bigger SiPM area) immediately lowers the fast



signal amplitude, which is unfavourable for fast timing. This is because it lowers the signal to noise ratio on the leading edge, according to equation (13), if one assumes that the electronic noise floor of the amplifier is not changing significantly. A further analysis of the slow recharging component can be found in Calò *et al* (2019), with the conclusion that the slow component, not very useful for fast timing, indeed becomes faster and larger in voltage amplitude if the input resistance R_{in} is decreased.

Sensing the current flowing through R_{in} a lower value of the input impedance would lead to a higher current spike according to equation (14), because the voltage jump is basically defined only by the ratio of capacitances. Qualitatively it could be stated that, if the input impedance of the front-end electronics is much lower compared to the passive terminal capacitance of the SiPM, at a given frequency, all the signal at this frequency is extracted. Then, in principle, the signal remains the same for large or small SiPM active areas. However, considering an SiPM capacitance of 1 nF and 1 Ω front-end input impedance of a current mode amplifier, this would mean in first order approximation a -3 dB bandwidth of 159 MHz, only. And, hence, the above argument renders only true for lower frequencies. In this case, the integrated charge flowing into the front-end would remain the same for a large or a small SiPM, consistent with an equal SPAD gain. But the large SiPM terminal capacitance will lower the bandwidth of the signal, and therefore the fast signal mediated via C_q will deteriorate, i.e. the signal rise time becoming slower and amplitude becoming smaller. On the other hand, in the case of a voltage amplifier, monitoring the voltage drop across the anode and cathode, bandwidths of 1 GHz and higher are easily possible. Nevertheless, the draw-back of this readout scheme is a very low voltage amplitude for large SiPMs with high passive terminal capacitance.


As previously introduced, in view of achieving good timing performance with SiPMs two front-end approaches are normally used (illustrated in figure 16), i.e. the voltage or current mode amplifier (Calò *et al* 2019). It should be mentioned as well that charge sensitive amplifiers could be used to read the signal from SiPMs, however, this has limitations in achieving good time resolution due to the high SiPM terminal capacitance. Still, due to the very good noise performance of charge amplifiers, a possible application of this type of amplifier could be using low gain SiPMs with small total equivalent capacitance (small cell size and small active area), especially if timing accuracy is not the most important parameter.

ASICs applying a voltage readout approach are for example SPIROC (Lorenzo *et al* 2013), EASIROC (Callier *et al* 2012), PETIROC (Fleury *et al* 2014) and PETA (Fischer *et al* 2009, Piemonte *et al* 2013). Using a voltage mode approach excellent timing can be achieved by using monolithic microwave integrated circuit (MMIC) radiofrequency (RF) amplifiers, commonly used for telecommunication. Designs such as this are explained in Yeom *et al* (2013), Cates *et al* (2018), Gundacker *et al* (2019). An interesting concept is to use a balun transformer to adapt the balanced SiPM signal to the unbalanced input of the amplifier (Cates *et al* 2018) which gives the additional advantage of suppressing common ground noise effectively, similar to a differential readout of the SiPM, e.g. as in the PETA chip or NINO ASIC (Anghinolfi *et al* 2004).

Examples of ASICs using a current readout approach are the NINO ASIC (Powolny *et al* 2011, Anghinolfi *et al* 2004), STIC3 (Stankova *et al* 2015), FlexTOT (Comerma *et al* 2013, Sarasola *et al* 2017) and TOPPET2 (Francesco *et al* 2016).

4. The digital SiPM

In the preceding chapters, most of the focus was placed on the analog SiPM. This is mainly due to its predominance in applications, e.g. PET or HEP, because of its mature production processes with high yield, achieving low dark count rates, high PDE and attractive costs. Nonetheless, on the hunt for the perfect photodetector the digital-SiPM might be the ultimate winner. In the fully digital or multi-digital SiPM each SPAD is connected to its own readout electronics (shown in figure 17(a)), including front-end and



digitization of the signal's time stamp via a time to digital converter (TDC) (Frach *et al* 2009, Mandai and Charbon 2012). Such a detector would give the full time information of a detected light pulse, e.g. from a scintillating crystal.

The first commercial digital SiPM was introduced by Philips (Frach *et al* 2009, Haemisch *et al* 2012). This device was specially designed to sense the light pulse of scintillating crystals for TOF-PET but was also successfully used to detect Cherenkov radiation in PET and HEP (Brunner and Schaart 2017, Frach 2012). The Philips d-SiPM records only one time stamp per scintillation event, which can be set on different probabilistic thresholds (Tabacchini *et al* 2014). In this sense this detector is very similar to the analog SiPM, with the important difference of combined front-end electronics and digitization on the device. This makes it easier for integration and to build complete PET detector rings (Degenhardt *et al* 2012). Examples of successful implementations of the d-SiPMs from Philips Digital Photon Counting into pre-clinical and clinical PET/MR systems was shown in (Weissler *et al* 2015, Schug *et al* 2015). These are prominent examples proving that d-SiPMs can be upgraded to full detector systems fairly easily, even in PET/MR systems, not losing significantly in performance with regard to experimental setups in the laboratory.

On the other hand, because of the integration of the electronics with the sensitive part (SPADs) it is costly to update the SPAD technology frequently. In addition, due to the combined integration of readout electronics and avalanche diodes within one wafer, the SPADs are bound to certain CMOS processes, which generally make them more noisy than SPADs of analog SiPMs. Switching off very noisy pixels via the quenching circuit can reduce the DCR, as shown in Mandai and Charbon, (2012), however, this is still falling behind customized production processes used for analog SiPMs in terms of dark noise.

Therefore newer research on the digital SiPM is moving in the direction of 3D assembling of the detector (Bérubé *et al* 2015, Nolet *et al* 2018, Nolet *et al* 2020). In figure 17(b) an example of a 3D integration is shown, that the group from Sherbrooke is currently working on Bérubé *et al* (2015). The 1st tier contains SPAD arrays with TSVs for each microcell, the 2nd tier contains the quenching circuit arrays and the 3rd tier contains the advanced signal processing and readout functionalities. First results show a very promising time resolution of this concept integrated in 65 nm CMOS with measured SPTR values of 17.5 ps FWHM (Nolet *et al* 2018).

Nevertheless, the drawback of such 3D integration is the enormous number of electronic readout channels coming with the price of high power consumption and complexity. An intermediate solution could be to couple a group of SPADs to its own readout-electronics with subsequent digitization. Here the main idea is that a smaller capacitance of this parallel connected group of SPADs, as compared to the whole SiPM, would lead to a higher SiPM signal, increased slew rate (dV/dt), and hence lowering the impact of the electronic noise. Following this logic, an array of small SiPMs (group of SPADs), all read-out individually by their own front-end with a time-stamp combination afterwards, could potentially lead to improved timing in e.g. TOF-PET. The advantages would be a lower number of readout channels compared to the fully digital SiPM, along with improved timing resolution. Groundbreaking research on the electronic design of this concept is discussed in Fernández-Tenllado *et al* (2019), finding that the optimal number of SPADs connected in parallel, readout by its own front-end, is fairly low around a few tens of SPADs only. Preliminary measurements of this idea with single SiPMs from HPK (S13360-6075V) compared to a 2×2 SiPM array (S13361-3075N-02) and a 3×3 SiPM array (S13361-2075N-03) coupled to a $6 \times 6 \times 3$ mm³ and a $6 \times 6 \times 20$ mm³ LYSO:Ce crystal, readout by the NINO front-end ASIC are given in Decker *et al* (2019).

Also in this contribution the conclusion is that a segmentation into a 3×3 array with $2 \times 2 \text{ mm}^2$ SiPMs (711 SPADs) each is not sufficient to improve the time resolution, which was explained by correlated noise sources like optical crosstalk having a higher impact on the CTR in the pixelated SiPM arrays.

Another interesting way of using all the advantages of the analog-SiPM but learning from the digital-SiPM architecture is to directly integrate the front-end electronics and time to digital conversion on the SiPM, which enables system-level advantages such as internal parasitic reduction for better single-photon timing resolution (SPTR), but also overall simplicity and compactness (Muntean *et al* 2018).

However, only the fully digital SiPM can provide the time stamps of each photon detected and, hence, allows for a pure mathematical (digital) treatment of all the information available (Lemaire *et al* 2020, Gundacker *et al* 2015, Venialgo *et al* 2015), therefore, the d-SiPM will always experience high attention and not only for academic research. Further reading on the digital SiPM can be found e.g. in the excellent review paper (Schaart *et al* 2016).

5. SiPMs in applications

Applications of SiPMs are naturally related to the detection of visible, near infrared and UV photons. Their good timing properties make them interesting for TOF-PET, fluorescence lifetime measurements in biology and other life sciences or LIDAR for autonomous driven cars. In this section attention will be given to SiPM timing properties regarding the detection of single photons and to when the SiPM is coupled to a scintillation material, as in the case of TOF-PET or HEP applications.

5.1. Single photon counting

SiPMs show extremely good single photon detection capability and excellent timing properties rendering them promising candidates for single photon counting applications. Typical fields are time correlated single photon counting in physics (Moses 1993, Brunner and Schaart 2017, Gundacker *et al* 2018) and biology (Caccia *et al* 2019). The SiPM's robustness to ambient light also makes this device interesting for astrophysics (Cherenkov telescopes) (Ambrosi *et al* 2016, Hahn *et al* 2018, Arcaro *et al* 2017) and LIDAR (Agishev *et al* 2013, Acerbi *et al* 2018c) for automotive and life sciences.


A draw-back of single photon counting with SiPMs is correlated noise, namely crosstalk and afterpulsing, which can deteriorate the best achievable timing resolution and biases the counted photon number. Another limitation, in the case of analog SiPMs, is that the maximum active area read out by one front-end channel is limited due to the fast increase of the device capacitance. One solution is to assemble many smaller SiPMs with their own front-end, with e.g. $3 \times 3 \text{ mm}^2$ active area. Despite these draw-backs the SiPM is gaining more and more attention in photon counting applications, as compared to PMTs or microchannel plate PMTs (MCP-PMTs), mainly due to its durability and the prospect of cheap production, implemented in well developed CMOS processes.

5.2. Sensing scintillation light with SiPMs

One application of SiPMs is to detect the produced optical, near-UV or VUV photons of scintillating materials. Especially in PET, crystals like LYSO:Ce, LSO:Ce or BGO are commonly used (Surti and Karp 2016, Conti and Bendriem 2019, Bisogni *et al* 2019).

Figure 18 shows the three building blocks of a scintillator-based detector applied in TOF-PET or HEP. The high energetic radiation in the form of charged minimum ionizing particles (MIPs) or gamma photons is absorbed in the scintillator and transformed to low energetic photons in the near-UV or visible range. There are losses in this transformation process and not all energy of the high energetic radiation can be used. This 'efficiency' is described by the light yield (LY) of the scintillator given in generated photons per deposited energy (ph/MeV or ph/keV). Additionally the scintillation process is not instantaneous having a certain scintillation time profile, which most of the time can be described fairly well with a multi-exponential shape having a certain rise time and decay time. This intrinsic scintillation rate $f(t)$ is defined in equation (15) as a bi-exponential function with τ_r the rise time, τ_d the decay time and $\Theta(t)$ the so-called Heaviside step function with $\Theta(t < 0) = 0$ and $\Theta(t \geq 0) = 1$. In full generality it can consist of one or more N bi-exponential terms with relative weights ρ_i . The percental weights in terms of the area or relative light abundance are then calculated according to equation (16).

$$f(t) = \sum_{i=1}^N \frac{\exp\left(-\frac{t}{\tau_{d,i}}\right) - \exp\left(-\frac{t}{\tau_{r,i}}\right)}{\tau_{d,i} - \tau_{r,i}} \cdot \rho_i \cdot \Theta(t) \quad (15)$$



$$R_i = \frac{\rho_i}{\sum_{i=1}^N \rho_i} \quad (16)$$

On top of the scintillation process Cherenkov photons can be produced if a detected charged particle traversing the scintillator is faster than the speed of light in the medium (c/n), given by the speed of light in vacuum (c) divided by the refractive index of the scintillation material (n). These Cherenkov photons are generated promptly with an instantaneous time structure and can be used as a fast time tagger. In TOF-PET applications upon the photo-absorption of the 511 keV gamma the released hot-electron shows enough kinetic energy to surpass the Cherenkov threshold in the heavy scintillator (e.g. LYSO, BGO) in order to produce these prompt photons. The Cherenkov light produced in BGO for example is about 17 photons in the 310–850 nm range (Gundacker *et al* 2020). Indeed Cherenkov emission in BGO has become suspect to a lot of attention in the TOF-PET community. This is because BGO would be the preferred material in PET due to its high density, high photofraction and relatively low cost of production, if the timing performance would be comparable to LYSO:Ce, which nowadays is widely used in TOF-PET.

After the light is produced by the scintillator it has to be transferred as efficiently as possible to the exit surface. Two quantities can be used to describe this process, the light transfer efficiency (LTE) and photon transfer time spread (PTS). The LTE is the fraction of light produced reaching the photodetector. It is generally dependent on the gamma conversion point in the crystal, i.e. the depth of interaction. Typical average LTE values (over many 511 keV interactions in the crystal in a PET like configuration) are 70% for 3 mm long crystals and 40% for 20 mm long crystals (Gundacker *et al* 2019). In addition to this loss of light the scintillation photons undergo a time delay and smearing by the transport in the crystal (Gundacker *et al* 2014). The PTS describes this quantity and is a complex function depending on the depth of interaction, hence, if the crystal is irradiated head-on or on the side etc. Several groups have worked on simulating the light transport in scintillators, either via Monte-Carlo simulations or by analytical considerations (Gundacker *et al* 2013, Cates *et al* 2015, Roncali *et al* 2017).

Last but not least the scintillation photons produced have to be detected by a photodetector (SiPM) and transformed into an electric signal, ultimately obtaining at least two quantities, i.e. the energy deposited in the crystal and the time of particle detection. Here, especially in PET and HEP, the SiPM has shown to be an almost ideal candidate, because of its very good time resolution (given by a good SPTR), high detection efficiency (PDE values), compactness, insensitivity to magnetic fields (especially for PET/MR applications) and the promise of being a very cost efficient detector once in mass-production. With the introduction of SiPMs it was possible to improve the coincidence time resolution in PET drastically to values close and lower than 100 ps FWHM in the laboratory and to values of 200 ps FWHM for commercial PET machines, for which a short overview will be given in the following chapter.

It should as well be mentioned that apart from timing applications in TOF-PET or HEP, SiPMs successfully found their way into gamma spectroscopy with scintillators. Mostly because they possess advantages such as being insensitive to magnetic fields, being able to operate at low bias voltages (below 50 V for newest devices), can be adapted to suit a variety of different scintillators emitting at different wavelengths and having no burn-in effect due to input light saturation. The drawbacks are non-linearity, temperature dependence of the gain, limited linear and dynamic ranges as well as crosstalk and afterpulsing. A complete review of SiPMs in gamma spectroscopy with scintillators can be found in Grodzicka-Kobylka *et al* (2019).




Figure 19. CTR shown as a function of the SPTR. CTR was measured with $2 \times 2 \times 3 \text{ mm}^3$ LSO:Ce:0.4%Ca crystals wrapped in Teflon coupled with Meltmount and normalized, as if all the SiPMs would have a PDE of 59%. Monte Carlo simulations of the CTR were performed for an analog SiPM with high-frequency readout and a hypothetical digital SiPM combining all timestamps via maximum likelihood estimation. The simulations include 7 Cherenkov photons produced. Reproduction from Gundacker *et al* (2020).

5.3. SiPMs in TOF-PET

SiPMs were successfully evaluated for TOF-PET in the early 2005's with the first commercial PET scanners using SiPMs appearing around 2014 and the latest machines even showing time resolutions in the 210 ps range (Surti and Karp 2016, Conti and Bendriem 2019). Currently a strong push for even better time resolutions towards 10–30 ps FWHM drives the SiPM development further in this field, e.g. (<https://the10ps-challenge.org>).

In figure 19 the CTR performance of different analog SiPMs available on the market is shown, as a function of the SiPM single photon time resolution (SPTR). This plot concentrates on the inherent performance of different SiPMs and therefore the PET timing was tested with a small $2 \times 2 \times 3 \text{ mm}^3$ LSO:Ce:Ca crystal. Presently, the best intrinsic SPTR measured with modern analog SiPMs is 70ps FWHM achieved with NUV-HD SiPMs from FBK, illuminating the whole active area of $4 \times 4 \text{ mm}^2$ (Cates *et al* 2018, Gundacker *et al* 2019). It seems that there is room for improving the CTR even further by using a digital SiPM. This is illustrated in figure 19 by comprehensive Monte-Carlo simulations (Gundacker *et al* 2016b, Gundacker *et al* 2020). The given values are only selective examples and many groups around the world are working on fast timing with SiPMs coupled to scintillators, especially in the field of PET, achieving very similar results. For example Cates and Levin (2016) showed a time resolution of 80 and 122 ps FWHM with 3 and 20 mm long LGSO:Ce crystals coupled to NUV-HD SiPMs, respectively. Further studies can be found in Vinke *et al* (2009), Powolny *et al* (2011), Seifert *et al* (2012), Gundacker *et al* (2013), Nemallapudi *et al* (2015), Gundacker *et al* (2016a), Cates and Levin (2016).

By implementing optimized readout and pushing the electronics bandwidth, state-of-the-art SiPMs are even capable of delivering a CTR of 100 ps with 20 mm long crystals (Gundacker *et al* 2019), as shown in figure 20(a). Even more interesting, SiPMs, due to their excellent SPTR, are capable of utilizing the few Cherenkov photons produced in BGO leading to a CTR of 277ps FWHM for 20 mm long crystal (see figure 20(b)) and 158 ps FWHM for 3 mm long crystals (Gundacker *et al* 2019). Because the produced Cherenkov photons are so few, not all 511 keV events lead to the detection of prompt photons, hence, BGO shows additional long tails caused by the standard BGO scintillation. Whether these tails are acceptable for true TOF-PET reconstruction still has to be investigated, however, it should be mentioned that via proper readout strategies events can be identified and stated as being either in the peak or the tail, comparable to event identification in metamaterial approaches (Turtos *et al* 2019). Nevertheless much attention is given to BGO and many groups performed extended studies on it (Brunner and Schaart 2017, Kwon *et al* 2016, Cates and Levin 2019, Gundacker *et al* 2020, Kratochwil *et al* 2020).

When building a detector it is also important to know how the SiPM area and crystal size influences the CTR, for which a short summary is given in table 1. Basically it can be observed that there is some light loss, if the crystal cross-section approaches the SiPM area. This effect is more pronounced for short crystals and almost negligible for longer crystals. Increasing the SiPM area causes some deterioration in CTR due to the larger SiPM capacitance, but it is not tremendous, if high-frequency readout of the SiPM is being used.




Table 1. Best obtainable CTR with different SiPM areas (HPK 50 μm SPAD pitch) and LYSO:Ce crystal geometries in TOF-PET using high frequency electronic readout. Crystals were wrapped in Teflon and coupled with optical glue Meltmount ($n = 1.58$). Both SiPM types (S13360-3050PE and S13360-6050PE) have been operated at the same 10.5 V overvoltage and 16 °C temperature.

crystal size (mm^3)	CTR (ps) (SiPM: $3 \times 3 \text{ mm}^2$)	CTR (ps) (SiPM: $6 \times 6 \text{ mm}^2$)
$2 \times 2 \times 3$	86 ± 2	91 ± 2
$3 \times 3 \times 3$	106 ± 1	101 ± 2
$6 \times 6 \times 3$	182 ± 2	117 ± 2
$2 \times 2 \times 20$	135 ± 2	134 ± 3
$3 \times 3 \times 20$	143 ± 1	136 ± 2
$6 \times 6 \times 20$	263 ± 2	159 ± 2

These examples should show the currently best achievable time resolutions and CTR limits with SiPMs in TOF-PET. Of course, building a PET detector with thousands of channels brings about various other problems. As there are integration and space limitations, limited power consumption, clock distribution only to name a few. Nevertheless, SiPMs have paved their way into TOF-PET due to the promise of excellent performances proven to deliver 100 ps CTR (in laboratory) and with the prospect of breaking this value even further towards 10 ps.

Prominent examples of commercial systems are the Vereos Digital TOF-PET/CT developed by Philips using digital SiPMs (Frach *et al* 2009) achieving a CTR of 300 ps FWHM, the Biograph Vision TOF-PET/CT from Siemens using analog SiPMs with refined readout architecture achieving a CTR of 210 ps FWHM (Conti and Bendriem 2019) and the launched whole body PET/CT from GE Healthcare named Discovery MI (Hsu *et al* 2017). The fact that all major players are using SiPMs in their high end TOF-PET/CT products can be seen as a confirmation of the overall superiority of SiPMs over PMTs, both in cost effectiveness and performance (Wagatsuma *et al* 2017).

5.4. SiPMs in PET/MR, SPECT/MR and Compton cameras

Hybrid scanners like SPECT/MR (single photon emission computed tomography combined with magnetic resonance imaging) and PET/MR were one of the main drivers of applying SiPMs in medical applications and paved the way for advanced TOF-PET systems discussed before (Bisogni *et al* 2019). The idea to combine PET with MR was evident after the success of PET/CT hybrid scanners in clinical applications. However, due to the magnetic fields present in MR-systems and the demand of having a simultaneous hybrid system, PMTs were not an option anymore (Zaidi and Del Guerra 2011). The first PET/MR systems were built using APDs as photodetectors, which could operate inside the MR. Interestingly, development on APDs was largely driven by HEP, as some calorimeters (e.g. CMS) operate in high magnetic fields and thus PMTs are not an option either (Deiters *et al* 2000). In the long run SiPMs comprised an attractive alternative to APDs, because of their much higher gain, faster rise time and much lower power supply voltage, which makes the integration in a system easier. After first attempts were made by several groups (e.g. Hong *et al* (2013)) the first

commercial PET/MR system based on SiPMs was produced by GE Healthcare (Grant *et al* 2016). Preclinical PET/MR systems equipped with the Philips d-SiPM were studied around 2012 with impressive CTR results of 213 ps FWHM and a spatial resolution of 0.73 mm FWHM (Weissler *et al* 2012, Weissler *et al* 2015).

Hybrid systems combining SPECT with MR are rare, because SPECT has evolved to use different detectors like CdTe or CZT semiconductors for direct detection of the gamma rays (Bisogni *et al* 2019). For instance one project using RGB-HD SiPMs from Fondazione Bruno Kessler (FBK, Italy) and CsI scintillators is the INSERT project which developed an integrated SPECT/MR breast system (Busca *et al* 2015, Busca *et al* 2014, Occhipinti *et al* 2018).

SiPM based Compton cameras using scintillator crystals (e.g. LaBr₃:Ce, CeBr₃ or GAGG:Ce) recently gained a lot of attention due to their cost effectiveness and portability (Llosá 2019), especially in view of environmental radiation monitoring in homeland security connected with nuclear weapon assays, nuclear disasters, radioactive debris, etc. There are also applications in hadron therapy treatment monitoring, as they are expected to provide higher efficiency than collimated cameras for prompt gamma-ray detection (Llosá *et al* 2012, Llosá *et al* 2013). Nevertheless, in hadron therapy the radiation damage of the SiPMs still remains an issue. HEP is facing similar problems, which will be subject for discussion in the following chapters.

5.5. SiPMs in HEP

In the last 10 years SiPMs have become increasingly popular in High Energy experiments. The first large experiment that used 60k SiPMs was the neutrino detector T2K. They used one of the first fully commercial $1.3 \times 1.3 \text{ mm}^2$, $50 \mu\text{m}$ pitch SiPMs from Hamamatsu (Vacheret *et al* 2011). The first Large Hadron Collider (LHC) experiment at CERN (European Organization for Nuclear Research) to use SiPMs was the Compact Muon Solenoid (CMS) general-purpose detector at the LHC. The CMS hadronic (HCAL) calorimeter is located in the large four Tesla CMS magnet and was originally readout by Hybrid Photo Diodes (HPDs) because of their magnetic field tolerance. In the last 5 years these HPDs were all replaced by $> 18 \text{ k}$ large area SiPMs leading to a better signal to noise ratio and long term stability as compared to the originally used HPDs. In order to satisfy the large linear range needed in the HCAL, i.e. one minimum ionizing particle (MIP) of about 2 GeV energy deposit to 500 GeV deposit for particle showers, CMS collaborated with multiple companies to develop $15 \mu\text{m}$ pitch SiPMs with > 4000 SPADs per square millimeter. The most challenging aspects of using SiPMs in a high energy experiment is an unusually high radiation environment and the gain and PDE dependence of the SiPMs versus temperature (breakdown voltage drift). Because the SiPMs are very compact the CMS-HCAL uses commercial peltier elements with a feedback loop in groups of 64 SiPMs packaged in 8 channel arrays to stabilize the temperature to 0.2°C .

Radiation damage creates defects in the silicon, which increase the leakage current (Moll 1999) and can be expressed in an increased DCR in SiPMs (equation (17)) and the equivalent noise charge (ENC) can be calculated as in equation (18).

$$\text{DCR} = \frac{I_d}{G \cdot q} \quad (17)$$

$$\text{ENC} = \sqrt{\text{DCR} \cdot T_I} \quad (18)$$

Here I_d is the SiPM current, G the SiPM gain at a defined overvoltage, q the elementary charge ($1.602 \cdot 10^{-19} \text{C}$) and T_I represents the integration time.

The dark count rate of most manufactures of SiPMs is below 100 kHz mm^{-2} . With radiation the DCR was expected to increase quickly with about 1 MHz mm^{-2} for every $10^9 \text{ neutrons cm}^{-2}$ (1 MeV equivalent) at an operating voltage of 3 V overvoltage at room temperature.

For example, figure 21 shows the average DCR increase for the 2.8 mm and 3.3 mm diameter SiPMs in the first year of operation in the CMS HCAL Endcap (HE). The total luminosity in CMS in the first year of operation with SiPMs was 67 fb^{-1} which gave 35 Mhz mm^{-2} at 18°C , equivalent to 2 p.e. noise for a 100 ns integration time of the plastic scintillator (Y11) pulses in the HCAL.

At around 27 fb^{-1} and at the end of the year beam stop, annealing of the SiPMs was clearly visible. However annealing at room temperature was measured to be maximum a factor of 2–3. The total dose in the HE is expected to be $2 \cdot 10^{11} \text{ n cm}^{-2}$ over the lifetime of the experiment for an expected integrated luminosity of 3000 fb^{-1} . The maximum radiation dose for the SiPMs in the HCAL is in the barrel section (HB) with a total dose of $1.5 \cdot 10^{12} \text{ n cm}^{-2}$. The expected DCR in the HB after 3000 fb^{-1} is 1.5 GHz and ENC of 12 p.e. at 3 V overvoltage at room temperature. To increase the S/N the peltiers can lower the temperate to 0°C in order to lower the DCR by a factor of four and ENC by a factor of two.




Figure 21. Average dark count rate increase as a function of luminosity of the HCAL SiPM at 18 °C and 3 V overvoltage.




Figure 22. Example of three CALICE 3×3 cm² scintillator tiles mounted on a PCB that holds one SiPM per tile. The left two scintillators are unwrapped to show the SiPM within the small dome at the centre of the tile, while right-most tile is wrapped with reflective foil.

5.1.1 CMS Endcap CE-H

After the successful operation of the SiPM in the HCAL there are two more projects in CMS that are considered for future upgrades that use SiPMs as their photodetector. The two projects are called the High Granularity Calorimeter (HGCAL) and Barrel Timing layer (BTL). The technical design reports of HGCAL are referenced in CMS, (2017). The HGCAL is mainly readout by 600 m² silicon sensors in the high radiation areas. In the lower radiation area with a fluence of $< 8 \cdot 10^{13}$ n cm⁻² it is possible to design a cheaper solution of plastic scintillating tiles with SiPM readout (Chang 2019).

In contrast to the existing HCAL HE, where the SiPMs are separated from the scintillators and readout by optical fiber connection between the scintillator and SiPMs, in this design the SiPMs are directly installed on small 3×3 cm² scintillating tiles. This so called SiPM-on-tile design was first introduced by the CALICE collaboration. The scintillator is formed into small tiles and scintillation light is directly readout by an SiPM that is optically coupled through a small ‘dimple’ in the centre of one face of each tile. The SiPMs are mounted on a printed circuit board which is then mated with the appropriate tiles. This system is illustrated in figure 22.

This geometry makes it possible to have a much finer segmentation to complement the fine segmentation and high granularity of the silicon sensors. The total amount of tiles with SiPMs needed for this project is 250 k for both End-Caps. The disadvantage of this SiPM on tile design is that the SiPM will see a much higher up to $8 \cdot 10^{13}$ 1 MeV equivalent neutron fluence. This is made possible by cooling the entire End-Caps to -30 °C.

5.1.2 BTL Timing layer

The Barrel Timing layer (BTL) is planned to be situated inside the Tracker support tube in CMS. Its main function is to measure the timing of minimum ionizing particle (MIP) signals with a precision of 30–50 ps (sigma single). The basic element of the BTL is a 16 channel array of $3 \times 3 \times 57$ mm³ LYSO:Ce crystals




Figure 23. (a) BTL 16 channel LYSO:Ce array. (b) BTL 16 channel SiPM array.




Figure 24. (a) Time resolution of the SiPM for different signal amplitudes for DCR = 0 GHz. (b) Additional time jitter due to DCR up to 35 GHz measured by injecting randomly distributed light on a BTL SiPM for a signal of 390 photoelectrons.

readout on each side by a 16 channel array of 3×3 mm² SiPMs (see figure 23). For the full installation the total number of 16 channel SiPM arrays is almost 30 000.

One of the major challenges is the radiation damage induced high dark count rate, which especially for timing is an issue. Interestingly the challenges are very close to applications with high background (ambient) light, as in the case of LIDAR. Especially for the case of the BTL timing layer the dependencies of the time resolution of dark counts have been studied in more detail and are presented below.

The timing resolution of a detector like BTL has many jitter contributions and can be summarized, as in equation (19). With σ_t^{clock} the clock distribution jitter, σ_t^{digi} the digitization induced jitter, σ_t^{ele} the electronic contribution, σ_t^{phot} the photostatistic contribution of the scintillation emission and σ_t^{DCR} the dark count rate induced noise equivalent timing jitter.

$$\sigma_t^{\text{BTL}} = \sigma_t^{\text{clock}} \oplus \sigma_t^{\text{digi}} \oplus \sigma_t^{\text{ele}} \oplus \sigma_t^{\text{phot}} \oplus \sigma_t^{\text{DCR}} \quad (19)$$

The timing performance drivers from the SiPM point of view are the photo-statistics (PDE and SPTR) and the noise term due to DCR (especially in the case of high DCR values). Thus major R&D efforts have been made towards the optimization of the SiPMs. The contribution from photostatistics at zero DCR is related to the stochastic fluctuations in the time-of-arrival of photons detected at the SiPM and is well known to be inversely correlated to the square root of the number of photoelectrons (N_{phe}), i.e. $\sigma_t^{\text{phot}} \propto \sqrt{1/N_{phe}}$.

A bench measurement (CMS 2019) of the timing dependence of the N_{phe} and DCR is shown in figure 24(a) using an LED with a pulse time spread of 350 ps rms. Due to the large expected radiation fluence of 2^{14} n cm⁻² in the BTL the DCR is expected to rise to 40 GHz even at an operating temperature inside the tracker tube of -30 °C. The DCR noise term will quickly be the dominant factor in the timing resolution. For the DCR measurement in figure 24(b) the LED intensity was first set to a value of about 390 photoelectrons yielding a time resolution, in absence of DCR, of about 15 ps sigma which is just above other jitter sources in the experimental setup.

The benefit of using a constant fraction algorithm $hf(t)$ as compared to a simpler leading edge approach $f(t)$ is shown to be important when the DCR increases (as can be seen in figure 24(b)). In order to obtain

$hf(t)$, the signal $f(t)$ is processed such that the waveform is inverted and delayed and then summed up with the original pulse resulting in a pulse defined by $hf(t) = f(t) - f(t + dt)$. In this way the resulting waveform has smaller baseline fluctuations from the DCR. Measuring the constant fraction timing resolution as a function of the N_{phe} for the highest 40 GHz DCR a $1/N_{\text{phe}}$ relation can be found.

To summarize, the contribution of the dark count rate (DCR) to the time resolution can be expressed as in equation (20).

$$\sigma_t^{\text{DCR}} \propto \frac{\sqrt{\text{DCR}}}{N_{\text{phe}}} \quad (20)$$

Here it can be seen that the DCR has the same influence as electronic noise to the time resolution with the noise amplitude proportional to the square root of the DCR. Further, the time resolution can be improved drastically by increasing the signal to noise ratio, i.e. the detected light intensity.

6. Discussion and outlook

The progress made in analog SiPMs over the last decade has been extensive, improving on all aspects, e.g. PDE, SPTR, afterpulse, crosstalk, etc. This, however, has set severe challenges on the front-end readout electronics, because the SiPM characteristics (signal shape and multiplication gain) have changed at an even pace bringing new devices almost every year. Today, the high maturity of analog SiPMs provides for more long-lived devices on the market, which allows for the optimization of the electronic readout systems. Additionally, newer devices while improving on aspects like PDE at different wavelengths, SPTR, etc tend to operate at similar overvoltages and have similar device capacitances. This makes the SiPM integration and modernization in systems easier to plan with a clear benefit for industrial products in the medical sector, automotive, biological applications and so forth.

Nevertheless, in medical imaging in particular the challenges of using SiPMs instead of PMTs lie in the high number of readout channels (several tens to thousands). Application-specific integrated circuits (ASICs) are able to cope with that number of channels, in part due to advancements regarding integrated design processes in deep-submicron technology, with 28 nm or 14 nm feature size. However, the drawback of using such highly integrated ASICs is the high cost and the need of design specialists. Another challenge is the assembly of the detector-system with proper routing of all signal lines. An early digitization, best directly on the SiPM, might be a viable solution to this problem. And indeed various research groups are working on this with analog SiPMs (Muntean *et al* 2018), digital SiPMs (Frach *et al* 2009) or fully 3D assembly of digital SiPMs (Bérubé *et al* 2012). Intermediate concepts on the way to the fully digital SiPM could be to amplify each SPAD signal with its own amplifier and combine the signals afterwards with an analog sum, or with an fast OR-gate (Nolet *et al* 2016).

The fully digital SiPM able of addressing each fired SPAD can in addition resolve the position of each impinging photon. This is important in Lidar cameras or the discrimination of small scintillator pixels in a crystal-matrix coupled to the SiPM in preclinical high-resolution small animal PET. New developments like position sensitive analog SiPMs are able to reduce the number of readout channels drastically with excellent spatial resolution of impinging photons on the SiPM. Examples of this technology are the linearly graded position-sensitive SiPM developed by FBK (Gola *et al* 2013, Ferri *et al* 2015, Du *et al* 2015), and the sensitivity encoded or interpolating SiPM (Schulz *et al* 2013, Fischer and Piemonte 2013).

Newest developments of SiPMs lead to extended PDE in the VUV (Gola *et al* 2019), which was shown to open new doors in the study of cross-luminescence crystals (Laval *et al* 1983) for fastest timing applications (Gundacker *et al* 2020). On the other side of the spectral range it was demonstrated that proper electric field design in the SPAD significantly improves the PDE in the red to infrared for LIDAR applications (Acerbi *et al* 2018c). Such electric field optimizations have a direct impact of boosting the SPTR and PDE of SiPMs.

With the SiPM having improved on so many levels, e.g. the PDE already reaches values of up to 70% at 410 nm, the SPTR is one remaining key parameter for further progress. For example, highest SPTR with values anticipated down to 10 ps is needed for ultimate timing in Cherenkov PET, which will only be possible with parallel efforts on electronic readout (Gundacker *et al* 2020, Cates *et al* 2018, Cates and Levin 2019).

Last but not least SiPMs due to their compactness, low power-consumption and continued integration of the readout electronics with further miniaturization will allow the realization of medical devices not possible with e.g. PMTs. As an example SiPMs were employed in the EndoTOFPET-US project, with the aim to built an endoscopic probe for pancreatic and prostate cancer, equipped with a PET head (Frisch 2013). In this special case, because of the missing ring geometry TOF becomes a very important aspect, where SiPMs can play to their strengths. Such novel systems could be used not only to improve diagnostic data but to guide surgical interventions as well (Bisogni *et al* 2019).

7. Conclusion

This paper introduced the basic working principles of SiPMs and discussed their most important defining parameters, e.g. dark count rate, crosstalk, afterpulsing, breakdown voltage, electrical model, etc. A highlight and closer explanation of applications where SiPMs are currently gaining more and more importance was given, e.g. in TOF-PET and HEP. The main spotlight was on the analog SiPM, merely because of its high maturity with excellent devices available on the market and intense research activities ongoing.

The analog SiPM is expected to see major improvements in single photon time resolution, which is currently a subject for in-depth research. Present-day PDE is already reaching values of up to 70% in devices with large single photon avalanche cells, and only little improvement in these devices can be expected. Nevertheless, in order to reduce correlated noise and increase the dynamic range of the SiPM, research is moving in the direction of smaller cell sizes. Hence, the PDE is still a subject for research and improvement, since in devices with small cell sizes, the effective fill factor plays a crucial role.

In this sense, the prospect of the analog SiPM might go in the direction of high dynamic range devices, with low crosstalk and afterpulsing together with excellent single photon and time resolution. Further research is continuing in devices applicable for LIDAR with improved detection sensitivity for photons in the red to infrared. On the other spectral range devices are being improved for the detection of UV light for dark matter search, applicable to the detection of cross-luminescence in scintillators. Besides the ongoing improvement of standard Silicon devices other materials are subject to research, like gallium arsenide (GaAs), indium gallium arsenide (InGaAs) or silicon carbide (SiC).

The digital SiPM might however ultimately be the device of the future, due to its promise of being the perfect photodetector by processing each single photon independently. Of course, research done on the analog SiPM is directly applicable to the digital SiPM, if 3D integration is applied. Just to mention one example, the digital SiPM would make it possible to build a single photon sensitive time imaging camera (allowing for lens-less LIDAR cameras).

Single photon detection with excellent time resolution is important for innumerable applications, truly rendering the story of SiPMs to be continued for a very long time.

Acknowledgments

This work has received support from the Crystal Clear Collaboration (CCC) and special thanks goes to Etienne Auffray and Paul Lecoq. The authors further want to thank Tina Vernon for thoroughly proofreading this manuscript. Last but not least we want to thank all physicists, engineers and technicians who we had the pleasure to discuss and work with the past years. Without that multitude of our really great colleagues this manuscript would not have been possible.

ORCID iD

Stefan Gundacker  <https://orcid.org/0000-0003-2087-3266>

References

- Acerbi F *et al* 2017 Cryogenic characterization of FBK HD near-UV sensitive SiPMs *IEEE Trans. Electron Devices* **64** 521–6
- Acerbi F, Ferri A, Gola A, Cazzanelli M, Pavesi L, Zorzi N and Piemonte C 2014 Characterization of single-photon time resolution: From single SPAD to silicon photomultiplier *IEEE Trans. Nucl. Sci.* **61** 2678–86
- Acerbi F, Ferri A, Zappala G, Paternoster G, Picciotto A, Gola A, Zorzi N and Piemonte C 2015 NUV silicon photomultipliers with high detection efficiency and reduced delayed correlated-noise *IEEE Trans. Nucl. Sci.* **62** 1318–25
- Acerbi F, Gola A, Regazzoni V, Paternoster G, Borghi G, Zorzi N and Piemonte C 2018a High efficiency, ultra-high-density silicon photomultipliers *IEEE J. Sel. Top. Quantum Electron.* **24** 3800608
- Acerbi F and Gundacker S 2019 Understanding and simulating SiPMs *Nucl. Instrum. Methods Phys. Res. A* **926** 16–35
- Acerbi F, Paternoster G, Gola A, Regazzoni V, Zorzi N and Piemonte C 2018b High-density silicon photomultipliers: Performance and linearity evaluation for high efficiency and dynamic-range applications *IEEE J. Quantum Electron.* **54** 4700107
- Acerbi F, Paternoster G, Gola A, Zorzi N and Piemonte C 2018c Silicon photomultipliers and single-photon avalanche diodes with enhanced NIR detection efficiency at FBK *Nucl. Instrum. Methods Phys. Res. A* **912** 309–14
- Agishev R, Comerón A, Bach J, Rodríguez A, Sicard M, Riu J and Royo S 2013 Lidar with SiPM: Some capabilities and limitations in real environment *Opt. Laser Technol.* **49** 86–90
- Ambrosi G, Corti D, Ionica M, Manea C, Mariotti M, Rando R, Reichardt I and Schultz C 2016 Large size SiPM matrix for Imaging Atmospheric Cherenkov Telescopes applications *Nucl. Instrum. Methods Phys. Res. A* **824** 125–7
- Anghinolfi F, Jarron P, Krummenacher F, Usenko E and Williams M C S 2004 NINO: An ultrafast low-power front-end amplifier discriminator for the time-of-flight detector in the ALICE experiment *IEEE Trans. Nucl. Sci.* **51** 1974–8
- Arcaro C, Corti D, Angelis A D, Doro M, Manea C, Mariotti M, Rando R, Reichardt I and Tesaro D 2017 Studies on a silicon-photomultiplier-based camera for Imaging Atmospheric Cherenkov Telescopes *Nucl. Instrum. Methods Phys. Res. A* **876** 26–30

- Bérubé B *et al* 2012 Development of a single photon avalanche diode (SPAD) array in high voltage CMOS 0.8 μm dedicated to a 3D integrated circuit (3DIC) 2012 IEEE Nuclear Symp. and Medical Conf. Rec. (NSS/MIC) (Anaheim, CA, 27 October–3 November 2012) (Piscataway, NJ: IEEE) pp 1835–9
- Bérubé B, Rhéaume V, Parent S, Maurais L, Therrien A C, Charette P G, Charlebois S A, Fontaine R and Pratte J 2015 Implementation study of single photon avalanche diodes (SPAD) in 0.8 μm HV CMOS technology *IEEE Trans. Nucl. Sci.* **62** 710–18
- Balygin K A, Zaitsev V I, Klimov A N, Kulik S P and Molotkov S N 2018 A quantum random number generator based on the 100-Mbit/s Poisson photocount statistics *J. Exp. Theor. Phys.* **126** 728–40
- Benaglia A, Gundacker S, Lecoq P, Lucchini M, Para A, Pauwels K and Auffray E 2016 Detection of high energy muons with sub-20 ps timing resolution using L(Y)SO crystals and SiPM readout *Nucl. Instrum. Methods Phys. Res. A* **830** 30–5
- Bisogni M G, Guerra A D and Belcari N 2019 Medical applications of silicon photomultipliers *Nucl. Instrum. Methods Phys. Res. A* **926** 118–28
- Bondarenko G, Dolgoshein B, Golovin V, Ilyin A, Klanner R and Popova E 1998 Limited Geiger mode silicon photodiode with very high gain *Nucl. Phys. B - Proc. Suppl.* **61** 347–52
- Bretz T *et al* 2016 Dynamic range measurement and calibration of SiPMs *J. Instrum.* **11** P03009
- Brunner S E, Gruber L, Marton J, Suzuki K and Hirtl A 2014 Studies on the Cherenkov effect for improved time resolution of TOF-PET *IEEE Trans. Nucl. Sci.* **61** 443–7
- Brunner S E and Schaart D R 2017 BGO as a hybrid scintillator/Cherenkov radiator for cost-effective time-of-flight PET *Phys. Med. Biol.* **62** 4421–39
- Busca P *et al* 2014 Simulation of the expected performance of INSERT: A new multi-modality SPECT/MRI system for preclinical and clinical imaging *Nucl. Instrum. Methods Phys. Res. A* **734** 141–6
- Busca P *et al* 2015 Experimental evaluation of a SiPM-based scintillation detector for MR-compatible SPECT systems *IEEE Trans. Nucl. Sci.* **62** 2122–8
- Buzhan P *et al* 2003 Silicon photomultiplier and its possible applications *Nucl. Instrum. Methods Phys. Res. A* **504** 48–52
- Buzhan P, Dolgoshein B, Ilyin A, Kaplin V, Klemin S, Mirzoyan R, Popova E and Teshima M 2009 The cross-talk problem in SiPMs and their use as light sensors for imaging atmospheric Cherenkov telescopes *Nucl. Instrum. Methods Phys. Res. A* **610** 131–4
- Caccia M, Nardo L, Santoro R and Schaffhauser D 2019 Silicon photomultipliers and SPAD imagers in biophotonics: Advances and perspectives *Nucl. Instrum. Methods Phys. Res. A* **926** 101–17
- Calò P P, Ciciriello F, Petrignani S and Marzocca C 2019 SiPM readout electronics *Nucl. Instrum. Methods Phys. Res. A* **926** 57–68
- Callier S, Taille C D, Martin-Chassard G and Raux L 2012 EASIROC, an easy & versatile ReadOut device for SiPM *Phys. Proc.* **37** 1569–76
- Cates J W, Gundacker S, Auffray E, Lecoq P and Levin C S 2018 Improved single photon time resolution for analog SiPMs with front end readout that reduces influence of electronic noise *Phys. Med. Biol.* **63** 185022
- Cates J W and Levin C S 2016 Advances in coincidence time resolution for PET *Phys. Med. Biol.* **61** 2255–64
- Cates J W and Levin C S 2019 Electronics method to advance the coincidence time resolution with bismuth germanate *Phys. Med. Biol.* **64** 175016
- Cates J W, Vinke R and Levin C S 2015 Analytical calculation of the lower bound on timing resolution for PET scintillation detectors comprising high-aspect-ratio crystal elements *Phys. Med. Biol.* **60** 5141–61
- Chang Y-W 2019 Construction and beam-tests of silicon and scintillator-SiPM modules for the CMS High Granularity Calorimeter for HL-LHC *Nucl. Instrum. Methods Phys. Res. A* **924** 301–4
- CERN 2017 The Phase-2 Upgrade of the CMS endcap calorimeter *Technical Report CERN-LHCC-2017-023, CMS-TDR-19* (Geneva: CERN)
- CERN 2019 Lab measurements of SiPM time resolution vs. Irradiation *CMS Note* (Geneva: CERN)
- Comerma A *et al* 2013 FlexToT—current mode ASIC for readout of common cathode SiPM arrays 2013 IEEE Nucl. Sci. Symp. and Medical Imaging Conf. (2013 NSS/MIC) (Seoul, 27 October–2 November 2013) (Piscataway, NJ: IEEE) pp 1–2
- Conti M and Bendriem B 2019 The new opportunities for high time resolution clinical TOF PET *Clin. Trans. Imaging* **7** 139–47
- Corsi F *et al* 2006 Electrical characterisation of silicon photo-multiplier detectors for optimal front-end design 2006 IEEE Nucl. Sci. Symp. Conf. Rec. (San Diego, CA, 29 October–1 November 2006) (Piscataway, NJ: IEEE) pp 1276–80
- Corsi F, Dragone A, Marzocca C, Guerra A D, Delizia P, Dinu N, Piemonte C, Boscardin M and Betta G F D 2007 Modelling a silicon photomultiplier (SiPM) as a signal source for optimum front-end design *Nucl. Instrum. Methods Phys. Res. A* **572** 416–18
- Cova S, Ghioni M, Lacaita A L, Samori C and Zappa F 1996 Avalanche photodiodes and quenching circuits for single photon-detection *Appl. Opt.* **32** 1956–76
- Cova S, Lacaita A, Ghioni M, Ripamonti G and Louis T A 1989 20-ps timing resolution with single-photon avalanche diodes *Rev. Sci. Instrum.* **60** 1104–10
- Dautet H, Deschamps P, Dion B, MacGregor A D, MacSween D, McIntyre R J, Trottier C and Webb P P 1993 Photon counting techniques with silicon avalanche photodiodes *Appl. Opt.* **32** 3894–900
- Decker S M, Pizzichemi M, Polesel A, Paganoni M, Auffray E and Gundacker S 2019 The Digital-Analog SiPM approach: a story of electronic and excess noise 2019 IEEE Nucl. Sci. Symp. and Medical Imaging Conf. (NSS/MIC) (Manchester, 26 October–2 November 2019) (Piscataway, NJ: IEEE) pp 1–5
- Degenhardt C, Rodrigues P, Trindade A, Zwaans B, Mülhens O, Dorscheid R, Thon A, Salomon A and Frach T 2012 Performance evaluation of a prototype positron emission tomography scanner using digital photon counters (DPC) 2012 IEEE Nucl. Sci. Symp. Med. Imaging Conf. Rec. pp 2820–4
- Deiters K *et al* 2000 Properties of the avalanche photodiodes for the CMS electromagnetic calorimeter *Nucl. Instrum. Methods Phys. Res. A* **453** 223–6
- Du J, Yang Y, Berg E, Bai X, Gola A, Ferri A, Zorzi N, Piemonte C and Cherry S R 2015 Evaluation of linearly-graded SiPMs for high resolution small-animal PET *Biomed. Phys. Eng. Express* **1** 045008
- Eckert P, Schultz-Coulon H C, Shen W, Stamen R and Tadday A 2010 Characterisation studies of silicon photomultipliers *Nucl. Instrum. Methods Phys. Res. A* **620** 217–26
- Fernández-Tenllado J, Ballabriga R, Campbell M, Gascón D, Gómez S and Mauricio J 2019 Optimal design of single-photon sensor front-end electronics for fast-timing applications 2019 IEEE Nucl. Sci. Symp. and Medical Imaging Conf. (NSS/MIC) (Manchester, 26 October–2 November 2019) (Piscataway, NJ: IEEE) pp 1–5
- Ferri A, Acerbi F, Gola A, Paternoster G, Piemonte C and Zorzi N 2015 Characterization of linearly graded position-sensitive silicon photomultipliers *IEEE Trans. Nucl. Sci.* **62** 688–93

- Fischer P, Peric I, Ritzert M and Konieczek M 2009 Fast self triggered multi channel readout ASIC for time- and energy measurement *IEEE Trans. Nucl. Sci.* **56** 1153–8
- Fischer P and Piemonte C 2013 Interpolating silicon photomultipliers *Nucl. Instrum. Methods Phys. Res.* **718** 320–2
- Fleury J, Callier S, de La Taille C, Seguin N, Thienpont D, Dulucq F, Ahmad S and Martin G 2014 Petiroc and citiroc: front-end ASICs for SiPM read-out and ToF applications *J. Instrum.* **9** C01049
- Frach T 2012 Optimization of the digital silicon photomultiplier for Cherenkov light detection *J. Instrum.* **7** C01112
- Frach T, Prescher G, Degenhardt C, de Gruyter R, Schmitz A and Ballizany R 2009 The digital silicon photomultiplier—principle of operation and intrinsic detector performance 2009 *IEEE Nucl. Sci. Symp. Conf. Rec. (NSS/MIC) (Orlando, FL, 24 October–1 November 2009)* (Piscataway, NJ: IEEE) 1959–65
- Francesco A D, Bugalho R, Oliveira L, Rivetti A, Rolo M, Silva J C and Varela J 2016 TOFPET 2: A high-performance circuit for PET time-of-flight *Nucl. Instrum. Methods Phys. Res. A* **824** 194–5
- Frisch B 2013 Combining endoscopic ultrasound with time-of-flight PET: the EndoTOFPET-US project *Nucl. Instrum. Methods Phys. Res. A* **732** 577–80
- Garutti E 2011 Silicon photomultipliers for high energy physics detectors *J. Instrum.* **6** C10003
- Gautam D K, Khokle W S and Garg K B 1988 Photon emission from reverse-biased silicon P-N junctions *Solid-State Electron.* **32** 219–22
- Gola A, Acerbi F, Capasso M, Marcante M, Mazzi A, Paternoster G, Piemonte C, Regazzoni V and Zorzi N 2019 NUV-sensitive silicon photomultiplier technologies developed at Fondazione Bruno Kessler *Sensors* **19** 308
- Gola A, Ferri A, Tarolli A, Zorzi N and Piemonte C 2013 A novel approach to position-sensitive silicon photomultipliers: first results 2013 *IEEE Nucl. Sci. Symp. and Medical Imaging Conf. (2013 NSS/MIC) (Seoul, 27 October–2 November 2013)* (Piscataway, NJ: IEEE) pp 1–4
- Gola A, Ferri A, Tarolli A, Zorzi N and Piemonte C 2014 SiPM optical crosstalk amplification due to scintillator crystal: effects on timing performance *Phys. Med. Biol.* **59** 3615
- Golovin V and Saveliev V 2004 Novel type of avalanche photodetector with Geiger mode operation *Nucl. Instrum. Methods Phys. Res. A* **518** 560–4
- Grant A M, Deller T W, Khalighi M M, Maramraju S H, Delso G and Levin C S 2016 NEMA NU 2-2012 performance studies for the SiPM-based ToF-PET component of the GE SIGNA PET/MR system *Med. Phys.* **43** 2334–43
- Green M A and Keevers M J 1995 Optical properties of intrinsic silicon at 300 K *Prog. Photovolt.: Res. Appl.* **3** 189–92
- Grodzicka-Kobyłka M, Moszynski M and Szczesniak T 2019 Silicon photomultipliers in gamma spectroscopy with scintillators *Nucl. Instrum. Methods Phys. Res. A* **926** 129–47
- Gruber L, Brunner S E, Marton J and Suzuki K 2014 Over saturation behavior of SiPMs at high photon exposure *Nucl. Instrum. Methods Phys. Res. A* **737** 11–18
- Gundacker S, Acerbi F, Auffray E, Gola A, Nemallapudi M V, Paternoster G, Piemonte C and Lecoq P 2016a State of the art timing in TOF-PET detectors with LuAG, GAGG and L(Y)SO scintillators of various sizes coupled to FBK-SiPMs *J. Instrum.* **11** P08008
- Gundacker S, Auffray E, Frisch B, Jarron P, Knapitsch A, Meyer T, Pizzichemi M and Lecoq P 2013 Time of flight positron emission tomography towards 100 ps resolution with L(Y)SO: an experimental and theoretical analysis *J. Instrum.* **8** P07014
- Gundacker S, Auffray E, Jarron P, Meyer T and Lecoq P 2015 On the comparison of analog and digital SiPM readout in terms of expected timing performance *Nucl. Instrum. Methods Phys. Res. A* **787** 6–11
- Gundacker S, Auffray E, Pauwels K and Lecoq P 2016b Measurement of intrinsic rise times for various L(Y)SO and LuAG scintillators with a general study of prompt photons to achieve 10 ps in TOF-PET *Phys. Med. Biol.* **61** 2802
- Gundacker S, Knapitsch A, Auffray E, Jarron P, Meyer T and Lecoq P 2014 Time resolution deterioration with increasing crystal length in a TOF-PET system *Nucl. Instrum. Methods Phys. Res. A* **737** 92–100
- Gundacker S, Turtos R M, Auffray E and Lecoq P 2018 Precise rise and decay time measurements of inorganic scintillators by means of x-ray and 511 keV excitation *Nucl. Instrum. Methods Phys. Res. A* **891** 42–52
- Gundacker S, Turtos R M, Auffray E, Paganoni M and Lecoq P 2019 High-frequency SiPM readout advances measured coincidence time resolution limits in TOF-PET *Phys. Med. Biol.* **64** 055012
- Gundacker S, Turtos R M, Kratochwil N, Pots R H, Paganoni M, Lecoq P and Auffray E 2020 Experimental time resolution limits of modern SiPMs and TOF-PET detectors exploring different scintillators and Cherenkov emission *Phys. Med. Biol.* **65** 025001
- Haemisch Y, Frach T, Degenhardt C and Thon A 2012 Fully digital arrays of silicon photomultipliers (dSiPM)—a scalable alternative to vacuum photomultiplier tubes (PMT) *Phys. Procedia* **37** 1546–60
- Hahn A, Dettlaff A, Fink D, Mazin D, Mirzoyan R and Teshima M 2018 Development of three silicon photomultiplier detector modules for the MAGIC telescopes for a performance comparison to PMTs *Nucl. Instrum. Methods Phys. Res. A* **912** 259–63
- Haitz R H 1964 Model for the electrical behavior of a microplasma *J. Appl. Phys.* **35** 1380
- Haitz R H, Goetzberger A, Scarletta R M and Shockley W 1963 Avalanche effects in silicon p-n junctions. I. Localized photomultiplication studies on microplasmas *J. Appl. Phys.* **34** 1581–90
- Herbert D J, Saveliev V, Belcari N, Ascenzo N D, Guerra A D and Golovin A 2006 First results of scintillator readout with silicon photomultiplier *IEEE Trans. Nucl. Sci.* **53** 389–94
- Hong K J *et al* 2013 A prototype MR insertable brain PET using tileable GAPD arrays *Med. Phys.* **40** 042503
- Hsu D F, Ilan E, Peterson W T, Uribe J, Lubberink M and Levin C S 2017 Studies of a next-generation silicon photomultiplier-based time-of-flight PET/CT system *J. Nucl. Med.* **58** 1511–18
- Ingargiola A, Assanelli M, Rech I, Guliniatti A and Ghioni M 2011 Avalanche current measurements in SPADs by means of hot-carrier luminescence *IEEE Photon. Technol. Lett.* **23** 1319–21
- Kalashnikov D and Krivitsky L 2014 Measurement of photon correlations with multipixel photon counters *J. Opt. Soc. Am B* **31** B25–33
- Kindt W J and Zeijl H W V 1998 Modelling and fabrication of Geiger mode avalanche photodiodes *IEEE Trans. Nucl. Sci.* **45** 715
- Klanner R 2019 Characterisation of SiPMs *Nucl. Instrum. Methods Phys. Res. A* **926** 36–56
- Korpar S, Dolenc R, Krizan P, Pestotnik R and Stanovnik A 2011 Study of TOF PET using Cherenkov light *Nucl. Instrum. Methods Phys. Res. A* **654** 532–8
- Kratochwil N, Gundacker S, Lecoq P and Auffray E 2020 Pushing Cherenkov PET with BGO via coincidence time resolution classification and correction *Phys. Med. Biol.* **65** 115004
- Kwon S I, Gola A, Ferri A, Piemonte C and Cherry S R 2016 Bismuth germanate coupled to near ultraviolet silicon photomultipliers for time-of-flight PET *Phys. Med. Biol.* **61** L38
- Lacaita A L, Zappa F, Bigliardi S and Manfredi M 1993 On the Bremsstrahlung origin of hot-carrier-induced photons in silicon devices *IEEE Trans. Electron Devices* **40** 577–82

- Laval M, Moszynski M, Allemand R, Cormoreche E, Guinet P, Odru R and Vacher J 1983 Barium fluoride—inorganic scintillator for subnanosecond timing *Nucl. Instrum. Methods Phys. Res.* **206** 169–76
- Lecomte R 2009 Novel detector technology for clinical PET *Eur. J. Nucl. Med. Mol. Imaging* **36** 69–85
- Lemaire W, Therrien A C, Pratte J and Fontaine R 2020 Dark count resilient time estimators for time-of-flight PET *IEEE Trans. Radiat. Plasma Med. Sci.* **4** 24–9
- Liu Z, Gundacker S, Pizzichemi M, Ghezzi A, Auffray E, Lecoq P and Paganoni M 2016 In-depth study of single photon time resolution for the Philips digital silicon photomultiplier *J. Instrum.* **11** P06006
- Llosá G *et al* 2013 First Compton telescope prototype based on continuous LaBr₃-SiPM detectors *Nucl. Instrum. Methods Phys. Res. A* **718** 130–3
- Llosá G 2019 SiPM-based Compton cameras *Nucl. Instrum. Methods Phys. Res. A* **926** 148–52
- Llosá G, Barrio J, Cabello J, Crespo A, Lacasta C, Rafecas M, Callier S, de La Taille C and Raux L 2012 Detector characterization and first coincidence tests of a Compton telescope based on LaBr₃ crystals and SiPMs *Nucl. Instrum. Methods Phys. Res. A* **695** 105–8
- Lorenzo S C D, Callier S, Fleury J, Dulucq F, la Taille C D, Chassard G M, Raux L and Seguin-Moreau N 2013 SPIROC: design and performances of a dedicated very front-end electronics for an ILC analog hadronic CALorimeter (AHCAL) prototype with SiPM read-out *J. Instrum.* **8** C01027
- Maes W, Meyer K D and Overstraeten R V 1990 Impact ionization in silicon: a review and update *Solid-State Electron.* **33** 705–18
- Mandai S and Charbon E 2012 Multi-channel digital SiPMs: Concept, analysis and implementation 2012 *IEEE Nucl. Sci. Symp. and Medical Imaging Conf. Rec. (NSS/MIC)* (Anaheim, CA, 27 October–3 November 2012) (Piscataway, NJ: IEEE) pp 1840–4
- Marano D *et al* 2013 Improved SPICE electrical model of silicon photomultipliers *Nucl. Instrum. Methods Phys. Res. A* **726** 1–7
- Marano D *et al* 2014 Silicon photomultipliers electrical model extensive analytical analysis *IEEE Trans. Nucl. Sci.* **61** 23–34
- McIntyre R J 1961 Theory of microplasma instability in silicon *J. Appl. Phys.* **32** 983–95
- McIntyre R J 1985 Recent developments in silicon avalanche photodiodes *Measurement* **3** 146–52
- Mik L, Kuciewicz W, Barszcz J, Sapor M and Glab S 2011 Silicon photomultiplier as fluorescence light detector *Proc. of the 18th Int. Conf. Mixed Design of Integrated Circuits and Systems—MIXDES 2011* (Gliwice, 16–18 June 2011) (Piscataway, NJ: IEEE) pp 663–6
- Moll M 1999 Radiation damage in silicon particle detectors *PhD Thesis* Hamburg University (DESYTHESIS-1999-040)
- Mora A D *et al* 2015 Fast silicon photomultiplier improves signal harvesting and reduces complexity in time domain diffuse optics *Opt. Express* **23** 13937
- Moses W 1993 A method to increase optical timing spectra measurement rates using a multi-hit TDC *Nucl. Instrum. Methods Phys. Res. A* **336** 253–61
- Moses W W 2003 Time of flight in PET revisited *IEEE Trans. Nucl. Sci.* **50** 1325–30
- Muntean A, Sachdeva A, Venialgo E, Gnecci S, Palubiak D, Jackson C and Charbon E 2018 A fully integrated state-of-the-art analog SiPM with on-chip time conversion 2018 *IEEE Nuclear Science Symp. and Medical Imaging Conf. Proc. (NSS/MIC)* (Sydney, Australia, 10–17 November 2018) (Piscataway, NJ: IEEE) pp 1–3
- Musienko Y, Heering A, Ruchti R, Wayne M, Karneyeu A and Postoev V 2015 Radiation damage studies of silicon photomultipliers for the CMS HCAL phase I upgrade *Nucl. Instrum. Methods Phys. Res. A* **787** 319–22
- Nemallapudi M V, Gundacker S, Lecoq P and Auffray E 2016 Single photon time resolution of state of the art SiPMs *J. Instrum.* **11** P10016
- Nemallapudi M V, Gundacker S, Lecoq P, Auffray E, Ferri A, Gola A and Piemonte C 2015 Sub-100 ps coincidence time resolution for positron emission tomography with LSO:Ce codoped with Ca *Phys. Med. Biol.* **60** 4635
- Nolet F, Dubois F, Roy N, Parent S, Lemaire W, Massie-Godon A, Charlebois S A, Fontaine R and Pratte J-F 2018 Digital SiPM channel integrated in CMOS 65 nm with 17.5 ps FWHM single photon timing resolution *Nucl. Instrum. Methods Phys. Res. A* **912** 29–32
- Nolet F, Lemaire W, Dubois F, Roy N, Carrier S, Samson A, Charlebois S A, Fontaine R and Pratte J-F 2020 A 256 pixelated SPAD readout ASIC with in-pixel TDC and embedded digital signal processing for uniformity and skew correction *Nucl. Instrum. Methods Phys. Res. A* **949** 162891
- Nolet F, Rhéaume V, Parent S, Charlebois S A, Fontaine R and Pratte J 2016 A 2D proof of principle towards a 3D digital SiPM in HV CMOS with low output capacitance *IEEE Trans. Nucl. Sci.* **63** 2293–9
- Occhipinti M *et al* 2018 Characterization of the detection module of the INSERT SPECT/MRI clinical system *IEEE Trans. Radiat. Plasma Med. Sci.* **2** 554–63
- Oldham W G, Samuelson R R and Antognetti P 1972 Triggering phenomena in avalanche diodes *IEEE Trans. Electron. Dev.* **19** 1056–60
- Otte A 2007 Observation of VHE gamma-rays from the vicinity of magnetized neutron stars and development of new photon-detectors for future ground based gamma-ray detectors *PhD Thesis* Technische Universität München
- Otte A N 2009 On the efficiency of photon emission during electrical breakdown in silicon *Nucl. Instrum. Methods Phys. Res. A* **610** 105–9
- Otte A N, Garcia D, Nguyen T and Purushotham D 2017 Characterization of three high efficiency and blue sensitive silicon photomultipliers *Nucl. Instrum. Methods Phys. Res. A* **846** 106–25
- Otte A N, Hose J, Mirzoyan R, Romaszkiwicz A, Teshima M and Thea A 2006 A measurement of the photon detection efficiency of silicon photomultipliers *Nucl. Instrum. Methods Phys. Res. A* **567** 360–3
- Pauwels K *et al* 2013 Single crystalline LuAG fibers for homogeneous dual-readout calorimeters *J. Instrum.* **8** P09019
- Piemonte C, Acerbi F, Ferri A, Gola A, Paternoster G, Regazzoni V, Zappala G and Zorzi N 2016 Performance of NUV-HD silicon photomultiplier technology *IEEE Trans. Electron. Dev.* **63** 1111–16
- Piemonte C and Gola A 2019 Overview on the main parameters and technology of modern silicon photomultipliers *Nucl. Instrum. Methods Phys. Res. A* **926** 2–15
- Piemonte C, Gola A, Tarolli A, Fisher P, Ritzert M, Schulz V and Solf T 2013 Performance of FBK SiPMs coupled to PETA3 read-out ASIC for PET application *Nucl. Instrum. Methods Phys. Res. A* **718** 345–6
- Powolny F *et al* 2011 Time-based readout of a silicon photomultiplier (SiPM) for time of flight positron emission tomography (TOF-PET) *IEEE Trans. Nucl. Sci.* **58** 597–604
- Re R, Martinenghi E, Mora A D, Contini D, Pifferi A and Torricelli A 2016 Probe-hosted silicon photomultipliers for time-domain functional near-infrared spectroscopy: phantom and *in vivo* tests *Neurophotonics* **3** 045004
- Renker D and Lorenz E 2006 Geiger mode avalanche photodiodes, history, properties and problems *Nucl. Instrum. Methods Phys. Res. A* **567** 48–56
- Renker D and Lorenz E 2009 Advances in solid state photon detectors *J. Instrum.* **4** P04004
- Roncali E and Cherry S R 2011 Application of silicon photomultipliers to positron emission tomography *Ann. Biomed. Eng.* **39** 1358–77

- Roncali E, Mosleh-Shirazi M A and Badano A 2017 Modelling the transport of optical photons in scintillation detectors for diagnostic and radiotherapy imaging *Phys. Med. Biol.* **62** R207
- Sarasola I, Nemallapudi M, Gundacker S, Sánchez D, Gascón D, Rato P, Marin J and Auffray E 2017 A comparative study of the time performance between NINO and FlexToT ASICs *J. Instrum.* **12** P04016
- Schaart D R, Charbon E, Frach T and Schulz V 2016 Advances in digital SiPMs and their application in biomedical imaging *Nucl. Instrum. Methods Phys. Res. A* **809** 31–52
- Scheuch F, Führen D, Hebbeker T, Heidemann C and Merschmeyer M 2015 Electrical characterization and simulation of SiPMs *Nucl. Instrum. Methods Phys. Res. A* **787** 340–3
- Schug D, Wehner J, Dueppenbecker P M, Weissler B, Gebhardt P, Goldschmidt B, Salomon A, Kiessling F and Schulz V 2015 PET performance and MRI compatibility evaluation of a digital, ToF-capable PET/MRI insert equipped with clinical scintillators *Phys. Med. Biol.* **60** 7045–67
- Schulz V, Berker Y, Berneking A, Omidvari N, Kiessling F, Gola A and Piemonte C 2013 Sensitivity encoded silicon photomultiplier—a new sensor for high-resolution PET-MRI *Phys. in Med. Biol.* **58** 4733–48
- Seifert S, van Dam H T, Huizenga J, Vinke R, Dendooven P, Löhner H and Schaart D R 2009 Simulation of silicon photomultiplier signals *IEEE Trans. Nucl. Sci.* **56** 3726–33
- Seifert S, van Dam H T, Vinke R, Dendooven P, Löhner H, Beekman F J and Schaart D R 2012 A comprehensive model to predict the timing resolution of SiPM-based scintillation detectors: Theory and experimental validation *IEEE Trans. Nucl. Sci.* **59** 190–204
- Serra N, Giacomini G, Piazza A, Piemonte C, Tarolli A and Zorzi N 2011 Experimental and TCAD study of breakdown voltage temperature behavior in n^+/p SiPMs *IEEE Trans. Nucl. Sci.* **58** 1233–40
- Stankova V *et al* 2015 STiC3—silicon photomultiplier timing chip with picosecond resolution *Nucl. Instrum. Methods Phys. Res. A* **787** 284–7
- Surti S and Karp J S 2016 Advances in time-of-flight PET *Phys. Medica* **32** 12–22
- Tabacchini V, Westerwoudt V, Borghi G, Seifert S and Schaart D R 2014 Probabilities of triggering and validation in a digital silicon photomultiplier *J. Instrum.* **9** P06016
- Ting D Z *et al* 2019 Advances in III-V semiconductor infrared absorbers and detectors *Infrared Phys. Technol.* **97** 210–216
- Turtos R M, Gundacker S, Auffray E and Lecoq P 2019 Towards a metamaterial approach for fast timing in PET: experimental proof-of-concept *Phys. Med. Biol.* **64** 185018
- Vacheret A *et al* 2011 Characterization and simulation of the response of multi-pixel photon counters to low light levels *Nucl. Instrum. Methods Phys. Res. A* **656** 69–83
- Venialgo E, Mandai S, Gong T, Schaart D R and Charbon E 2015 Time estimation with multichannel digital silicon photomultipliers *Phys. Med. Biol.* **60** 2435–52
- Vincent G, Chantre A and Bois D 1979 Electric field effect on the thermal emission of traps in semiconductor junctions *J. App. Phys.* **50** 5484–7
- Vinke R, Löhner H, Schaart D R, van Dam H T, Seifert S, Beekman F J and Dendooven P 2009 Optimizing the timing resolution of SiPM sensors for use in TOF-PET detectors *Nucl. Instrum. Methods Phys. Res. A* **610** 188–91
- Vinogradov S, Vinogradova T, Shubin V, Shushakov D and Sitarsky C 2011 Efficiency of solid state photomultipliers in photon number resolution *IEEE Trans. Nucl. Sci.* **58** 9–16
- Wagadarikar A A, Katz S, Ivan A and Dolinsky S 2013 Performance of low afterpulsing probability multi-pixel photon counters for time-of-flight positron emission tomography 2013 *IEEE Nucl. Sci. Symp. and Medical Imaging Conf. (2013 NSS/MIC)* (Seoul, 27 October–2 November 2013) (Piscataway, NJ: IEEE) pp 1–5
- Wagatsuma K, Miwa K, Sakata M, Oda K, Ono H, Kameyama M, Toyohara J and Ishii K 2017 Comparison between new-generation SiPM-based and conventional PMT-based TOF-PET/CT *Phys. Medica* **42** 203–210
- Weissler B *et al* 2012 Design concept of world's first preclinical PET/MR insert with fully digital silicon photomultiplier technology 2012 *IEEE Nuclear Sci. Symp. and Medical Imaging Conf. Rec. (NSS/MIC)* (Anaheim, CA, 27 October–3 November 2012) (Piscataway, NJ: IEEE) pp 2113–16
- Weissler B *et al* 2015 A digital preclinical PET/MRI insert and initial results *IEEE Trans. Med. Imaging* **34** 2258–70
- Yeom J Y, Vinke R and Levin C S 2013 Optimizing timing performance of silicon photomultiplier-based scintillation detectors *Phys. Med. Biol.* **58** 1207–20
- Zaidi H and Del Guerra A 2011 An outlook on future design of hybrid PET/MRI systems *Med. Phys.* **38** 5667–89
- Zappala G, Acerbi F, Ferri A, Gola A, Paternoster G, Zorzi N and Piemonte C 2016 Set-up and methods for SiPM Photo-Detection Efficiency measurements *J. Instrum.* **11** P08014
- Zimmermann R, Braun F, Achtnich T, Lambercy O, Gassert R and Wolf M 2013 Silicon photomultipliers for improved detection of low light levels in miniature near-infrared spectroscopy instruments *Biomed. Opt. Express* **4** 659–66